

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

MAR 4981

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 6/2W-28
State Permit No. _____

(1) OWNER:

Name A.L. FUGH
Address RT. 1 BOX 239 BROOKS ORE.

(2) LOCATION OF WELL:

County MARION Driller's well number 794
1/4 Section 28 T. 6 R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
10" Diam. from TOP ft. to 60 ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 3/12 in. by 3/4 in. ?
_____ perforations from 33 ft. to 59 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal PUTTLE CLAY & CEMENT
Depth of seal 19 ft. Was a packer used? _____
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 6 ft. below land surface Date 24 Dec 62
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 600 gal./min. with 45 ft. drawdown after 4 hrs.
" " " " "
" " " " "
" " " " "
Bailey test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 60 ft. Depth of completed well 60 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
BROWN CLAY	3	6
blue clay	6	20
BROWN CLAY	20	33
BROWN SAND AND GRAVEL	33	60

SET PUMP 50 TO 55 FT.

Work started DEC. 17 1962 Completed 24 DEC. 1962
Date well drilling machine moved off of well DEC. 24 1962

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
(Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, ORE.

Drilling Machine Operator's License No. 141

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date DEC. 26, 1962