

RECEIVED MARI... 4482
 NOV 10 1962 WATER WELL REPORT
 STATE OF OREGON
 STATE ENGINEER (Please type or print)
 SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

State Well No. _____
 State Permit No. _____

6/2W-28

(1) OWNER:

Name Jack A Oglesby
 Address Brooks Oregon RT. I BOX 27I
c/o Ronald E. Jones, Brooks, Ore.

(2) LOCATION OF WELL:

County marion Driller's well number 790
 1/4 1/4 Section 28 T. 6S R. 2W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12. _____

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
 Irrigation Test Well Other Cable Jetted
 Dug Bored

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

10 Diam. from top ft. to 63 ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Milles
 Size of perforations in. by in.
184 perforations from 184 ft. to _____ ft.
38 perforations from 38 ft. to 62 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal PUDDLE CLAY
 Depth of seal 20 ft. Was a packer used? _____
 Diameter of well bore to bottom of seal _____ in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 7 ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? DEILLER
 Yield: 550 gal./min. with 8 ft. drawdown after 4 1/2 hrs.
 " " " "
 " " " "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
 Depth drilled 63 ft. Depth of completed well 63 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	4
BROWN CLAY	4	9
BROWN SANDY SILT	9	26
SAND & GRAVEL	26	63

Work started NOV 1 19 ____ Completed NOV 7 19 62
 Date well drilling machine moved off of well _____ 19 ____

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
 (Person, firm or corporation) (Type or print)
 Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 141

[Signed] Emil O. Beier
 (Water Well Contractor)

Contractor's License No. 2 Date NOV. 7, 19 62