

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED
MAY 2 1960

MAR 4491

WATER WELL REPORT

State Well No. 65/2W-28E

STATE ENGINEER STATE OF OREGON G1786

State Permit No.

(1) OWNER:

Name Ann Garbaino
Address R 2 Box 401 Salem Ore.

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
1/4 1/4 Section 28 T. 6S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from top ft. to 128 ft. Gage 279
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used mill
SIZE of perforations 7/8 in. by 1 1/2 in.
632 perforations from 76 ft. to bottom ft.
perforations from 40 ft. to 137 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
" Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 90 ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 4-19-60
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Ann Garbaino Date April 20, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: gal./min. with ft. drawdown after hrs.
" 300 " 97 " 3 "
" 250 " 68 " 3 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 130 ft. Depth of completed well 128 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>top dirt</u>	<u>0</u>	<u>4</u>
<u>silty clay</u>	<u>4</u>	<u>15</u>
<u>sandy silt</u>	<u>15</u>	<u>35</u>
<u>sand & gravel cemented</u>	<u>35</u>	<u>72</u>
<u>sand & gravel loose</u>	<u>72</u>	<u>82</u>
<u>stiff blue shale</u>	<u>82</u>	<u>90</u>
<u>sand & gravel</u>	<u>90</u>	<u>94</u>
<u>blue shale</u>	<u>94</u>	<u>96</u>
<u>sand & gravel black</u>	<u>96</u>	<u>98</u>
<u>grayish brown shale</u>	<u>98</u>	<u>109</u>
<u>gravel & shale</u>	<u>109</u>	<u>110</u>
<u>shale thin strips of</u>		
<u>sand & gravel</u>	<u>110</u>	<u>130</u>

Work started 3-25 1960 Completed 4-19 1960

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME IRVING SEARS
(Person, firm, or corporation) (Type or print)

Address R 1 Hurwath Ave.

Driller's well number 563

[Signed] Irving Sears
(Well Driller)

License No. 8 Date 4-19, 1960