State Well No. 6/2W-2966 STATE ENGINEER, SALEM, OREGON 97315 ENGINEER OF OREGON WIND within 30 days from the dateSALEM. OREGON of well completion. State Permit No. ... Ronald E Jones Trustee Vater Raht in the name - & (1) OWNER: (10) LOCATION OF WELL: Name Driller's well number 1599 Harvey Lea Address 7326 Lakeside Drive NE Salem, Oregon 14 Section 29 T.68 R. 2W Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): New Well IX Reconditioning [ Deepening | Abandon  $\square$ If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Rotary Driven [ Domestic 🔲 Industrial 🖂 Municipal 🖂 ft. below land surface. Date 2-25-72 Static level 7 Cable Jetted [7] Irrigation M Test Well 

Other Dug Artesian pressure lbs. per square inch. Date CASING INSTALLED: Threaded | Welded 🔽 (12) WELL LOG: Diameter of well below casing .... 8 " Diam. from top ft. to 93 ft. Gage 250 Depth drilled QX ft. Depth of completed well ......" Diam, from ...... ft, to ...... ft. Gage ..... Formation: Describe color, texture, grain size and structure of materials; ..... Diam. from ...... ft. to ...... and show thickness and nature of each stratum and aguifer penetrated, with at least one entry for each change of formation. Report each change in PERFORATIONS: position of Static Water Level and indicate principal water-bearing strata. Perforated? Yes | No. Type of perforator used Mills MATERIAL Size of perforations 3/8 in. by 2 Top Soil 2 0 296 perforations from 35 ft. to 63 ft. Gray Clay 2 20 48 perforations from 87 ft. to 92 Yellow Clay 20 32 Brown sand and gravel ..... perforations from ...... ft. to .... 32 63 Blue Clay 63 87 (7) SCREENS: Well screen installed? ☐ Yes 🛣 No Black sand and gravel Manufacturer's Name ...... Type ...... Model No. .... Diam. Slot size Set from ft. to ft. Diam. ..... Slot size ...... Set from ..... ft. to ..... ft. Drawdown is amount water level is lowered below static level (8) WELL TESTS: Was a pump test made? Yes | No If yes, by whom? Driller Yield: 270 gal./min. with ft. drawdown after 300 350 Bailer test gal./min. with ft. drawdown after Artesian flow g.p.m. perature of water Depth artesian flow encountered ..... ft. Work started 2-12-72 Completed 2-26-72 Date well drilling machine moved off of well Feb. 26, 197219 (9) CONSTRUCTION: Well seal-Material used Cement and Puddle Clay Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my Well sealed from land surface to \_\_\_\_\_\_\_ft. best knowledge and belief. [Signed] Bonuld W. Morton Date 2-26-72, 19. Diameter of well bore below seal .......8 in. Drilling Machine Operator's License No. 536 Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks Brand name of bentonite ..... Water Well Contractor's Certification: Number of pounds of bentonite per 100 gallons This well was drilled under my jurisdiction and this report is .....lbs./100 gals. true to the best of my knowledge and belief. Was a drive shoe used? 

▼ Yes □ No Plugs ....... Size: location ....... ft. Name WILLAMETTE DRILLING COMPANY Did any strata contain unusable water? 🗌 Yes 🖼 No (Type or print) (Person, firm or corporation)

ft.

depth of strata

\_\_\_\_\_ft. to \_\_\_\_\_

Was well gravel packed? ☐ Yes 🎛 No Size of gravel: ....

Type of water?

Method of sealing strata off

Salem. Oregon 97303