

(1) OWNER: SALEM, OREGON  
Name GAIL ZYSET  
Address 1565 Roosevelt  
SALEM, OREGON

(2) LOCATION OF WELL:  
County MARION Owner's number, if any—  
R. F. D. or Street No. County Road 626 Rt. 1, Brooks  
Bearing and distance from section or subdivision corner  
1,163 ft. South 1,992 ft. east of  
North west corner of  
Sec. 29 T6S R2W

(3) TYPE OF WORK (check):  
New well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) EQUIPMENT:  
Rotary   
Cable   
Dug Well

(6) CASING INSTALLED:  
Threaded  Welded   
FROM 0 ft. to 88 ft. 8" Diam. 1250 Wall  
Gage or Wall  
Type and size of shoe or well ring Cast steel  
Describe joint Welded

If gravel packed  
Diameter of Bore from ft. to ft.

(7) PERFORATIONS:  
Type of perforator used NONE  
SIZE of perforations in., length, by in.  
FROM ft. to ft. perf per foot No. of rows

SCREENS:  
Give Manufacturer's Name, Model No. and Size  
None

(8) CONSTRUCTION:  
Was a surface sanitary seal provided?  Yes  No To what depth 88 ft.  
Were any strata sealed against pollution?  Yes  No  
If yes, note depth of strata  
FROM ft. to ft.  
METHOD OF SEALING Casing only

(9) WATER LEVELS:  
Depth at which water was first found 42 ft.  
Standing level before perforating No perforations ft.  
Standing level after perforating 28 ft.  
Log Accepted by:  
[Signed] Gail Zyset Dated \_\_\_\_\_, 19\_\_  
Owner

MAR 4530

(10) WELL TESTS:  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. draw down after hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Shut-in pressure \_\_\_\_\_ lbs. per square inch.  
Bailer test no g.p.m. with \_\_\_\_\_ ft. drawdown  
Temperature of water 58 Was a chemical analysis made?  Yes  No  
Was electric log made of well?  Yes  No

(11) WELL LOG:  
Diameter of well, 8" inches.  
Total depth 88 ft. Depth of completed well 88 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.  
0 ft. to 42 ft. Sandy Clay, Brown to grey Clay.  
42" 53" Cemented Sand  
53" 72" Yellow sandy silt  
72" 88" Cemented Sand & Gravel  
88" 88" Gravel - per gravel  
" 88" 88" 88"  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "  
" " " "

Ground elevation at well site 143 feet above mean sea level.  
Work started OCT 14 1956 Completed OCT 18 1956  
Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME DUFFIELD BROS (Person, firm, or corporation) (Typed or printed)  
Address 4045 BLUFF ST, SALEM, ORE  
Driller's well number  
[Signed] Edward H. Duffield (Well Driller)  
License No. 15 Dated OCT 22, 1956