NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filled with the STATE ENGINEER, SALEM, OREGON 97310 Within 30 days from the date of well completion. STATE ENGINEER, SALEM, OREGON 97310 STATE ENGINEER, SALEM, OREGON 97310 Of well completion.

State Permit No. .

SALEM, OREGON

G-4517

(1) OWNER:	(11) LOCATION OF WELL:		
Name Harvey I. Lea	County Marion Driller's well m	ımber 1314	_
Address 7326 Lakeside Dr. NE Salen, Oregon	14 14 Section 28 T. 68	R. 277	W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	n corner	
New Well Deepening Reconditioning Abandon			
If abandonment, describe material and procedure in Item 12.	-		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well i	below casing	
Cable Z Jetted Domestic Industrial Municipal	Depth drilled 90 ft. Depth of compl		ft.
Dug ☐ Bored ☐ Irrigation 🛣 Test Well ☐ Other ☐	Formation: Describe color, texture, grain size		aterials:
CASING INSTALLED: Threaded Welded M	and show thickness and nature of each stratu	m and aquifer per	netrated,
	with at least one entry for each change of form in position of Static Water Level as drilling pro		
ft. to ft. Gage	MATERIAL	From To	SWL
ft. to ft. Gage	m		
PERFORATIONS: Perforated? Fr Yes No.	Top Soil	0 1	
	Brown Clay Brown Sendy silt	20 40	
hide have been a second as	Brown sand & gravel	40 80	
Size of perforations 2 in. by 3/8 in.	Gray Clay	80 90	5
460 perforations from 40 ft. to 80 ft.			
perforations from ft. to ft.			
perforations fromft. toft.			
perforations fromft. toft.			
perforations from ft. to ft.			
(7) SCREENS: Well screen installed? ☐ Yes ☑ No			
Manufacturer's Name			
Type Model No			
Diam. Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WATER LEVEL: Completed well.			
Static level 5 ft. below land surface Date 5-16-68			
	737-0-11		
lbs. per square inch Date			
(9) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? 🛣 Yes 🗌 No If yes, by whom?			
d: 600 gal./min. with 10 ft. drawdown after 2 hrs.	Work started May 10, 19619 Complete	ed _{May} 16, 196	5,219
500 " 8 " 2 "	Date well drilling machine moved off of well 75		19
			
D. D. J.	Drilling Machine Operator's Certification: This well was constructed under my di	rect supervision	Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above		
Artesian flow g.p.m. Date	knowledge and belief.		
Temperature of water Was a chemical analysis made? Yes No	[Signed] (Drilling Machine Operator)	Dateliny 16,	, 19.6.8.
(10) CONSTRUCTION:			
Well seal—Material usedDrill cuttings Puddle clay	Drilling Machine Operator's License No151		
Depth of seal ft.	Water Well Contractor's Certification:		
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is		
Were any loose strata cemented off? Yes No Depth	true to the best of my knowledge and belief.		
Was a drive shoe used? 🖼 Yes 🔲 No	NAME WILLAMET E DRILLING COMPANY (Person, firm or corporation) (Type or print)		
Did any strata contain unusable water? 🗌 Yes 🔯 No			
Type of water? depth of strata	Address 7641 35th Ave. NE S. lem. Oregon 97303		
Method of sealing strata off	ESO D R		
	[Signed] (Water Well Contract	tor)	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:			
Gravel placed fromft. to ft.	Contractor's License No2 Date La	<u>у то, од ",</u>	19