

4540
MARI...

WATER WELL REPORT
STATE OF OREGON

State Well No. 6/2w-29
State Permit No.

(1) OWNER:

Name J.W. FITTS
Address BOX 268 TR. 1 -
BROOKS ORR

(2) LOCATION OF WELL:

County MARION Owner's number, if any -
1/4 1/4 Section T. 6S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
" Diam. from ft. to ft. Gage 32#
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

SIZE of perforations 3/4 in. by 3 in.
400 perforations from 72' ft. to 92' ft.
400 perforations from 118' ft. to 122' ft.
236 perforations from 122' ft. to 139' ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 9" T ft.
Material used in seal - PUMPS COVERED
Did any strata contain unusable water? Yes No
Type of water? SANDY Depth of strata 100-7064
Method of sealing strata off W/HEAD

(10) WATER LEVELS:

Static level 25' ft. below land surface Date 7-5-60
Artesian pressure lbs. per square inch Date

Log Accepted by: J.W. Fitts
[Signed] Date 19.....
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 1000 gal./min. with 20' ft. drawdown after 3 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12" inches.

Depth drilled 141 ft. Depth of completed well 141 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	3
YELLOW CLAY SANDY	3	45
MUCKY SAND	45	60
SAND (MEDIUM GRAIN)	60	64
CEMENTED GRAVEL	64	80
WATER GRAVEL 2"	80	81
CEMENTED GRAVEL W.B.	81	92
BLUE CLAY SANDY	92	97
CEMENTED GRAVEL	97	106
BLUE CLAY STICKY	106	113
BLUE CLAY SANDY	113	118
WATER SAND + GRAVEL	118	122
3" 50% SAND	122	137
CEMENTED GRAVEL	122	137
WATER SAND + GRAVEL	137	139
BLUE CLAY STICKY	139	141

Work started 6-25-1960 Completed 7-5-1960

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.H. SHIPCO & SONS
(Person, firm, or corporation) (Type or print)

Address 2505 BROOKS ST - SALEM, O

Driller's well number

[Signed] P.J. Seefeld
(Well Driller)

License No. 6 Date 7-5-1960