

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

**RECEIVED** WATER WELL REPORT  
MAR 7 1966 STATE OF OREGON  
**RECEIVED** MAR 10 1966  
STATE ENGINEER STATE ENGINEER

MARI 4563  
6/2w-30

(1) OWNER: SALEM OREGON  
Name EDITH HILTON  
Address 4335 YORK AVENUE SALEM ORE

(2) LOCATION OF WELL:  
County MARION Driller's well number  
¼ Section 30 T. 6S R. 2W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
10" Diam. from 0 ft. to 126 ft. Gage 7  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used MILLS  
Size of perforations 3/8 in. by 2 1/2 in.  
800 perforations from 68 ft. to 89 ft.  
80 perforations from 118 ft. to 122 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
in. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:  
Well seal—Material used in seal BENTONITE  
Depth of seal 47 ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 13 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? SANDY Depth of strata 47 TO 65  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 13 ft. below land surface Date 2-17-66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? STETLER SUPPLY  
Yield: 600 gal./min. with 27 ft. drawdown after 2 hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 57 Was a chemical analysis made?  Yes  No

(12) WELL LOG: Diameter of well below casing 10"  
Depth drilled 126 ft. Depth of completed well 126 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	47
CONGLOMERATE	47	65
GRAVEL - 1" -	65	66
CONGLOMERATE YELLOW	66	83
GRAVEL COARSE	83	85
CONGLOMERATE	85	90
CLAY YELLOW STICKY	90	92
CLAY BLUE STICKY	92	98
CLAY BLUE SANDY	98	113
CONGLOMERATE BLUE COLOR	113	118
GRAVEL 1" -	118	119
CONGLOMERATE	119	122
CLAY BLUE COLOR-STICKY	122	126

Work started 2-12-1966 Completed 2-17-1966  
Date well drilling machine moved off of well 2-17-1966

(13) PUMP:  
Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME J.A. SNEED + SONS (Person, firm or corporation) (Type or print)  
Address 3710 SILVERTON RD. N.E. SALEM ORE  
Drilling Machine Operator's License No. 187  
[Signed] J.A. Sneed (Water Well Contractor)  
Contractor's License No. 6 Date 2-17-1966