

RECEIVED MAR 27 1959 MARK 4564

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT STATE OF OREGON SALEM, OREGON

State Well No. 6/2w-30A(2) State Permit No.

(1) OWNER:

Name LAKE LABISH SCHOOL DIST. 102
Address % Fred Remington, Clerk
P.O. Box 564, Salem, Oregon

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
NE 1/4 NE 1/4 Section 30 T. 6 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner
Well is located East 1269.84 feet and North 24 deg. 51.5' East 2055 feet, thence South 89 deg. 37' West 380 feet from the South West corner of Louis Vandale D.L.C. in T. 6 S. R. 2 W. of Will. Let.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well SCHOOL

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from Top ft. to 89 ft. Gage 17.02#
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 25 ft.
Material used in seal— Puddled Clay
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 28 ft. below land surface Date 2-5-59
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Charles D. Holcomb Date 2-14, 1959
(Owner)
Board Member

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? E. Beier
Yield: 20 gal./min. with 8 ft. drawdown after 24 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 89 ft. Depth of completed well 89 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Yellow Clay	3	28
Yellow Sandy Clay	28	48
Blue Clay	48	80
Black Sand & Gravel	80	89
(Water)		

(NOTE)

Oregon State Board of Health
Lab. Test # 1765 2-6-59

FINDINGS: This water conforms with accepted bacteriological standards of purity for drinking water

Work started 1-24-59 19 Completed 2-5-59 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Emil O. Beier (Person, firm, or corporation) (Type or print)
Address 7555 O'Neil Rd. Salem, Oregon

Driller's well number 470

[Signed] Emil O. Beier (Well Driller)

License No. 89 Date 2-5-59, 19