

Stettler Supply Co.

1810 Lana Ave.
Salem, Oregon

6/20-30A
Marion

WELL TEST CARD

Well Diameter 10' Depth 180' Cased to _____

Well straight? Yes Depth after pumping _____

Well casing perforated at _____

Formation of water bearing strata Sand + Gravel

Test pump setting 138 Length of air line 131

Static level - Before test 39 After test _____

Static air pressure _____

Capacity _____ Pressure on air line _____ Pumping level _____ Time _____

650 GPM 12 Lbs. 103 Feet 1-1/2 Minutes

500 20 85 1-hr

Just Pumping 2-hr

Did well clear up? Yes Some fine sand + dirty

Water for about 2 hrs.

Name Dr. G. R. R. R.
Address _____

RECEIVED
FEB 28 1969
STATE ENGINEER
SALMON

NE 1/4 Sec. 30
+ 65
R 20

Finished drilling 12-16-68