

WATER WELL REPORT (as required by ORS 537.765)

65/2W	-31cd

PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:	(10) LOCATION OF WELL by legal description:
Name Cletus L. Woods	County Marion SE 1/4 SW 1/4 of Section 31 of
Address 3950 Chemwa Rd. N.E.	Township 6S , Range Range WM.
City Salem, Oregon 97303 State	Tax Lot Lot Block Subdivision Job # 2503
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address)
· ·	**************************************
New Well X Deepening Reconditioning Abandon	ditch on Lake Labish
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL of COMPLETED WELL:
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
Rotary Air Driven Domestic 🔯 Industrial Dunicipal D	Depth at which water was first found 30 ft.
Rotary Mud Dug Irrigation Withdrawal Reinjection	Static level 0 ft. below land surface. Date 4/25/84
Other: Piezometric Grounding Test	Artesian pressure lbs. per square inch. Date
Doted C Messacrio C Conditions	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled 68 ft. Depth of completed well 68 ft.
Threaded □ Welded □	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of
8 Diam. from +1 ft. to 68 ft. Gauge 250	formation. Report each change in position of Static Water Level and indicate principal
"Diam. fromft. to	water-bearing strata.
LINER INSTALLED: Steel Plastic Threaded Welded	MATERIAL From To SWL
	Black Peat Type Soil 0 12
ft. Gauge	Gray Clay 12 30
(6) PERFORATIONS: Perforated? X Yes □ No	Cemented Brown Sand and Gravel 30 61
Size of perforations 7/16 in. by 2 3/4 in.	Brown Sand and Gravel 61 68
96 perforations from	Drown band and Graver Or Oo
perforations from ft. to ft.	
perforations from ft. to ft.	
	DECEMBE
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	IIIN 1 1 1984
Type	
Diam. Slot Size Set from ft. to ft. to ft.	WATER RESOURCES DEPT
Diam. Slot Size Set from It. to Drawdown is amount water level is lowered	SALEM, OREGON
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom?	
d: gal./min. with ft. drawdown after hrs.	
Air test gal./min. with drill stem at ft. hrs.	
3.7	
Built tool	
Artesian flow g.p.m. Depth artesian flow encountered	
pperature of water Depth artesian flow encountered it.	Date work started 4/20/84 /completed 4/25/84
(9) CONSTRUCTION: Special standards: Yes ♥ No □	Date well drilling machine moved off of well 4/25/84 19
Well seal-Material used 8-mesh Graulated Bentonite	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and
Diameter of well bore to bottom of seal in.	information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	10
Amount of sealing material	[Signed], 19,
How was cement grout placed? Bentonite placed in dry annulus	(bontable) (table titon bonner artist and the contraction of the contr
immediately after placement of first joint xm	Bond SB 34721 Issued by: Oregon Auto (Surety Company Name)
of casing.	
Was pump installed? Type HP Depth ft.	On behalf of Mark D. Beier (type or print name of Water Well Constructor)
Was a drive shoe used? Wes Do Plugs Size: location ft.	
Did any strata contain unusable water?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
Type of Water? depth of strata	
Method of sealing strata off	(Signed) (Water Well Constructor)
Was well gravel packed?	(Dated) 4/25/84
Gravel placed fromft. toft.	(Dateu)