AUG 10 WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No.	6/2W-3	1
DINIE METT 140.		*****

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

7			
(1) OWNER:	(11) WELL TESTS: Drawdown is amount water level is lowered below static level		
Name GEORGE A. STUPFEL	Was a pump test made? Wes No If yes, by whom? DRILLER		
Address 5455 PORTLAND RD. N.E.	Yield: 300 gal./min. with 40 ft, drawdown after 4 hrs.		
SALEM, OREGON	<u>" I50 " 20 " 4 "</u>		
(2) LOCATION OF WELL:	<u>" I00 " IQ " 4 "</u>		
MAD TON 952	Bailer test gal./min, with ft. drawdown after hrs.		
ZT - 6 - 2W	W.M. Artesian flow g.p.m. Date		
Hearing and distance from section or subdivision corner	Temperature of water Was a chemical analysis mader Ites No		
Beating and distance from sooten of Santa	(12) WELL LOG: Diameter of well below casing		
	Depth drilled I26 ft. Depth of completed well I26 ft.		
	Formation: Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.		
· · · · · · · · · · · · · · · · · · ·	MATERIAL FROM TO		
(3) TYPE OF WORK (check):	TOP SOIL 0 I5		
New Well-F Deepening ☐ Reconditioning ☐ Aband			
andonment, describe material and procedure in Item 12.	SAND 30 35		
Potenty II Driven	- CAMD		
Domestic Industrial Municipal Cable Jetted	GRAVEL 75 I24		
Irrigation Test Well Other Dug Bored			
(6) CASING INSTALLED: Threaded □ Welded X			
8 "Diam. from TOP ft. to I26 ft. Gage 250			
"Diam. fromft. toft. Gage			
ft. Gage			
(7) PERFORATIONS: Perforated? ■ Yes □ No			
Type of perforator used MTLLS			
Size of perforations in. by 3/8 in. 2			
580 perforations from 75 ft. to 124	ft.		
perforations from ft. to	ft.		
perforations from ft. to			
perforations from ft. to	ft,		
perforations fromft. to	ft.		
(8) SCREENS: Well screen installed? ☐ Yes ▼No			
Manufacturer's Name			
Type Model No			
A Slot size Set from ft. to	Work started AUG I I9604 . Completed AUG 8 I9694		
Diam. Slot size Set from ft. to			
(9) CONSTRUCTION:	(13) PUMP:		
Well seal—Material used in sealCEMENT & PUDDLE C	T.AY Manufacturer's Name		
Depth of seal 20 ft, Was a packer used?	Туре: Н.Р.		
Diameter of well bore to bottom of seal in.	Water Well Contractor's Certification:		
Were any loose strata cemented off? Yes No Depth			
Was a drive shoe used?▼ Yes □ No	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was well gravel packed? Yes No Size of gravel:			
Gravel placed from ft. to ft.	NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print)		
Did any strata contain unusuable water? Yes No			
Type of water? depth of strata	Address RT. 2 BOX 276 SALEM, OREGON		
Method of sealing strata off	Drilling Machine Operator's License No		
(10) WATER LEVELS:	E 10 Ri		
Static level 50 ft. below land surface Date 8/8/	/64 [Signed] Omil (Water Well Contractor)		
Artesian pressure lbs. per square inch Date	Contractor's License No. 2 Date AUG. 10 196,419		