

RECEIVED

MAR... 4.606

SEP 23 1963 WATER WELL REPORT

State Well No. 6/2u-31

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER STATE OF OREGON SALEM, OREGON

State Permit No.

(1) OWNER:

Name JOHN KOLDUSEK
Address 5552 PORTLAND RD. SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Owner's number, if any-
Bearing and distance from section or subdivision corner
3700 FT. SOUTH + 1300 FT. WEST FROM N.E. COR.
OF SEC. 36 T. 6 S. OF W.M.

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal []
Irrigation [] Test Well [] Other [x] TRAILER COURT

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 8" ABOVE ft. to 84 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [x] No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [x] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [x] Yes [] No To what depth? 4.0 ft.
Material used in seal- BEITONITE + PUDDLED CLAY
Did any strata contain unusable water? [] Yes [x] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 47 ft. below land surface Date 5-7-62
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date 19

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom? DRILLER
Yield: 8 gal./min. with 7 ft. drawdown after 3 hrs.
JUST TO SEE IF WATER WOULD CLEAR UP
Bailer test 35 gal./min. with 8 ft. drawdown after 1 hr.
Artesian flow x g.p.m. Date
Temperature of water [x] Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 84 ft. Depth of completed well 84 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include TOP SOIL-BROWN, CLAY-GRAYISH-BROWN, FINE SANDY-CLAY-BROWN, MED. SAND WITH CLAY-GRAYISH-BR., MED. CONGLOM.-MED. HARD-GRAY (w.B.), MED SAND & GRAVEL-BLUEISH-GRAY (w.B).

Work started 4-30 1962 Completed 5-7 1962

(13) PUMP:

Manufacturer's Name
Type: H.P. 3

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADELI & SONS (Person, firm, or corporation) (Type or print)

Address R.F.E. 3, Box 169, SILVERTON, OREGON

Driller's well number

[Signed] Paul R. Stadel (Well Driller)

License No. 296 Date 6-30 1962