

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Please type or print)
(Do not write above this line)

State Well No. 6/2w-31E
State Permit No. _____

RECEIVED
MAY 19 1968

G-4468

well #3 MARI... 4/615

(1) OWNER:

Name Urban S. Payer STATE ENGINEER
Address 456 1/2 St. Street Salem, Oregon OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
" Diam. from 8 ft. to 8.0 ft. Gage 2.50
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used _____
Size of perforations 3 in. by 3 1/8 in.
505 perforations from 40 ft. to 75 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 1 ft. below land surface Date Feb. 12/68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? Therrell
Flow: 400 gal./min. with 6 ft. drawdown after 1 hrs.
640 " " 10 " " 1 "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used 25' Red Puddle Clay
Depth of seal _____ ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 30-3 T. 6 S R. 2 West W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8.5"
Depth drilled 85 ft. Depth of completed well 85 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>Red Moss</u>	<u>0</u>	<u>22</u>	
<u>Blue Clay</u>	<u>22</u>	<u>30</u>	
<u>Gravel</u>	<u>30</u>	<u>75</u>	
<u>Blue Clay</u>	<u>75</u>	<u>84</u>	
<u>Dry Sand</u>	<u>84</u>	<u>85</u>	

Work started Feb 9 1968 Completed Feb. 14 1968
Date well drilling machine moved off of well Feb. 12 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J. F. Terrell Date Feb. 16, 1968
(Drilling Machine Operator)
Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J. F. Terrell (Type or print)
Address RT #1, Box 57 Corvallis, Ore.
[Signed] Mrs. Jean S. Terrell
(Water Well Contractor)
Contractor's License No. 4460 Date Feb. 16, 1968