

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED**  
 MAR 2 1970  
 STATE ENGINEER  
 SALEM, OREGON

**WATER WELL REPORT**

(Please type or print)  
 above this line)

4662  
 MARION

State Well No. 6/2W-32da

State Permit No.

G 5176

**(1) OWNER:**

Name ALLEN VIBBERT  
 Address 5490 HAZEL GREEN RD N.E. SALEM ORE.

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**CASING INSTALLED:**

10" Diam. from 0 ft. to 193 ft. Gage 4  
 " Diam. from ..... ft. to ..... ft. Gage .....  
 " Diam. from ..... ft. to ..... ft. Gage .....

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used MILLS  
 Size of perforations 3/8 in. by 2 1/2 in.  
800 perforations from 114' ft. to 191' ft.  
30 perforations from 76' ft. to 77' ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name ..... Model No. ....  
 Type ..... Slot size ..... Set from ..... ft. to ..... ft.  
 Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

**(8) WATER LEVEL: Completed well.**

Static level 32' 4" ft. below land surface Date 2-25-70  
 Artesian pressure ..... lbs. per square inch Date .....

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level.

Was a pump test made?  Yes  No If yes, by whom? STETTLER SUPPLY  
 Yield: 420 gal./min. with 18 ft. drawdown after 1 1/2 hrs.  
820 " 46 " 1 " "

Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.

Artesian flow ..... g.p.m. Date .....

Temperature of water 51 Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used BENTONITE  
 Depth of seal 66' ft.  
 Diameter of well bore to bottom of seal 14" in.  
 Were any loose strata cemented off?  Yes  No Depth .....  
 Was a drive shoe used?  Yes  No  
 Did any strata contain unusable water?  Yes  No  
 Type of water? SANDY depth of strata 53' to 66'  
 Method of sealing strata off CASED  
 Was well gravel packed?  Yes  No Size of gravel: .....  
 Gravel placed from ..... ft. to ..... ft.

**(11) LOCATION OF WELL:**

County MARION Driller's well number .....  
 1/4 Section 32 T. 65 R. 24 W.M.  
 Bearing and distance from section or subdivision corner .....

**(12) WELL LOG:**

Diameter of well below casing 10"

Depth drilled 193' ft. Depth of completed well 193' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	1	
CLAY YELLOW	1	15	
SILT YELLOW	15	53	
CLAY GRAY-SANDY	53	66	
CONGLOMERATE	66	78	
CLAY YELLOW	78	100	
CONGLOMERATE - Blue	100	102	
CONGLOMERATE YELLOW	102	121 1/2	
GRAVEL & SAND 2"	121 1/2	123	32' 4"
CONGLOMERATE WITH INTERMITTENT SMALL VEINS	123	193	32' 4"

Work started 2-11- 1970 Completed 2-25 1970

Date well drilling machine moved off of well 2-25 1970

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] B.F. Sneed Date 2-25, 1970  
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 187

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS  
 (Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD SALEM ORE.

[Signed] B.F. Sneed  
 (Water Well Contractor)

Contractor's License No. 6 Date 2-25, 1970