NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the WATER WELL REPORT MARIE OF OREGON

State Well No. ...

6/2w-32 E

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

E ESTATE OF OREGON

Please type or print)

On the print of the control of the con

State Permit No.

<u> </u>	G-4416		
(1) OWNER: Roy B. Aker, Mrs. H.B. Aker & Elmer McClaughry	(11) LOCATION OF WELL:	3.007	
	County Marion Driller's well number		
Address 4590 Labish Gardens Rd. NE Salem	4 4 Section 32 T. 6S R.2	W.M.	
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corne	·r	
New Well ∰ Deepening ☐ Reconditioning ☐ Abandon ☐			
If abandonment, describe material and procedure in Item 12.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(10) THEFT TOC.		
Rotary Driven Domestic Industrial Municipal	(12) WELL LOG: Diameter of well below casing		
Cable T Jetted Johnson T Test Well Other	Depth drilled 200 ft. Depth of completed well 200 ft.		
(5) CASING INSTALLED: Threaded Welded 72	Formation: Describe color, texture, grain size and str and show thickness and nature of each stratum and with at least one entry for each change of formation. in position of Static Water Level as drilling proceeds.	aquifer penetrated, Report each change	
" Diam. from ft. to ft. Gage	MATERIAL From	To SWL	
" Diam. from ft. to ft. Gage	Top Soil (5	
PERFORATIONS: Perforated? Tyes No.		5 21	
Type of perforator used Mills	Brown clay & gravel 2:	I 35	
Size of perforations 2 in. by 3/8 in.	Brown clay & gravel 3		
800 perforations from 40 ft. to 199 ft.	Brown clay 8		
perforations fromft. toft.		0 200 5	
perforations from ft. to ft.	Brown sand and gravel, clay	200	
perforations from ft. to ft.		+	
perforations from ft. toft.	No. of the last of		
(7) SCREENS: Well screen installed? Ves. 77 No.			
(7) SCREENS: Well screen installed? ☐ Yes % No Manufacturer's Name			
Type	· · · · · · · · · · · · · · · · · · ·		
Diam. Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WATER LEVEL: Completed well.			
tic level 5 ft. below land surface Date 1/17/68			
Artesian pressure lbs. per square inch Date	: `		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? Yes No If yes, by whom? Driller	Work started 11/11/67 19 Completed 1/	77/68 19	
d: 600 gal./min. with 32 ft. drawdown after 4 hrs.	Date well drilling machine moved off of well 1/18/		
<u> </u>		00	
<u>" 400 " 22 " 4 "</u>	Drilling Machine Operator's Certification: This well was constructed under my direct so	unamidian Mata	
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are knowledge and belief.		
Artesian flow g.p.m. Date		/m = / = =	
Temperature of water 54 Was a chemical analysis made? Yes No	[Signed] Date Date	/18/68, 19	
(10) CONSTRUCTION:	Drilling Machine Operator's License No.	51	
Well seal—Material used Drill cuttings & puddle column Depth of seal 20 ft.	- G. Y		
Depth of sealft. Diameter of well bore to bottom of seal14in.	Water Well Contractor's Certification:		
Were any loose strata cemented off? Yes No Depth	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? M Yes □ No	NAME WILLAMETTE DRILLING COMPANY (Type or print)		
Did any strata contain unusable water? Yes No			
Type of water? depth of strata	Address 7641 35th Ave. NE (Rt.	. 2) Salem,	
Method of sealing strata off	Grand Da Rosa		
Was well gravel packed? Yes To Size of gravel:	[Signed]		
Gravel placed from ft to ft	Contractor's License No. 2 Date 1/18/	/68 10	