

MAR 4 1958

RECEIVED

APR 24 1958

(1) OWNER:

Name Alvin J. VanCleave
Address Route 2 Box 404 Salem, Oregon

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Max Wymore
Yield: gal./min. with ft. drawdown after hrs.
Pump Test Below " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? Yes No

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
NE 1/4 NE 1/4 Section 32 T. 6S. R. 2W. W.M.

Bearing and distance from section or subdivision corner

203.0 ft. South and 1248.9 ft. West from the Section corner common to Sections 28, 29, 32 and 33

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 146 ft. Depth of completed well 146 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Brown Clay	3	18
Brown sandy clay	18	63
Brown Sand (Water)	63	67
(Water) Brown Sand & Gravel	67	97
Blue Sandy Clay	97	110
(Water) Black Sand & Gravel	110	120
Blue clay & Gravel	120	125
(Water) Black Sand & Gravel	125	146

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10 ID " Diam. from top ft. to 146 ft. Gage 31.20 ft.
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used MILLS
SIZE of perforations in. by 1 1/2 in.
520 perforations from 67 ft. to 97 ft.
450 perforations from 110 ft. to 146 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 20 ft.
Material used in seal— Puddled Clay
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 32 ft. below land surface Date 4-20-57
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Alvin J. VanCleave Date May 16 1957
(Owner)

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Max Wymore (Type or print)
(Person, firm, or corporation)

Address Rt. 2 Salem, Oregon

Driller's well number 1331

[Signed] Max Wymore (Well Driller)

License No. 24 Date 4-20-57, 19.....

by Marion VanCleave