

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON
 (Please type or print)

MARI...705

State Well No. 6/2W-33

State Permit No. _____

(1) OWNER:

Name ERNEST ZELINSKI
 Address 527 HAZELGREEN Rd
SALEM, ORE

(2) LOCATION OF WELL:

County MARION Driller's well number _____
1/4 Section 33 T. 6S R. 2W W.M.
 Bearing and distance from section or subdivision corner
Drilled gravel feed 2 feet
South of present 12" well
by Arrow Drilling 6/4/63

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
4" Diam. from 0 ft. to 20 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ in. Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
 Depth of seal 19 ft. Was a packer used? _____
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: 3/4
 Gravel placed from 0 ft. to 124 ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 37 ft. below land surface Date 5/14/64
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? SELF
 Yield: 800 gal./min. with 17 ft. drawdown after 6 hrs.
 " " " "
 " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
 Depth drilled 90 ft. Depth of completed well _____ ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	3
BROWN Clay	3	26
CAVITY	26	41
BROWN SANDY Clay	41	70
BROWN SANDY Clay with small GRAVEL	70	90

HOLE WAS DRILLED FOR GRAVEL FEED DRILLED & CASSED 90 FT. 8" CASING - PULLED OUT ALL 8" PUT IN 20'-4" CASING

Pump test made with air compressor and tank

Work started 4/16 1964 Completed 5/14 1964
 Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:

Manufacturer's Name PEERLESS with Layne + Bowler
 Type: Turbine BOWLER & SHAFT #1030 H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Mike Schneiders Equip Co
 (Person, firm or corporation) (Type or print)
 Address Star Route Box 97 Astoria

Drilling Machine Operator's License No. 374

[Signed] Mike Schneiders
 (Water Well Contractor)

Contractor's License No. 387 Date 6-12-64, 1964