

RECEIVED

MARI... 4706

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER STATE OF OREGON (Please type or print)

SALEM, OREGON

State Well No. 6/2W-33

State Permit No.

(1) OWNER:

Name Ernest Bielinski
Address 527 Hazel Green Rd. Salem Ore

(2) LOCATION OF WELL:

County Multnomah Driller's well number
1/4 Section 33 T. 6S R. 22 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []
abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 7.1 ft. to 124 ft. Gage 3/8
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Torch
Size of perforations 4 in. by 6 in.
660 perforations from 50 ft. to 124 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Cement
Depth of seal 15 ft. Was a packer used? no
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 37 ft. below land surface Date 6/3/63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [] No If yes, by whom?
Yield: 600 gal./min. with 64 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well below casing
Depth drilled ft. Depth of completed well ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top Soil, Brown Clay, Sandy Clay, Gravel, Cement Gravel, etc.

Work started 5/22 1963 Completed 6/4 1963
Date well drilling machine moved off of well 6/4 1963

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harold Dullin & Supplies (Person, firm or corporation)
Address 729 N Main Newberg
Drilling Machine Operator's License No. 82
[Signed] Harold Dullin (Water Well Contractor)
Contractor's License No. 117 Date 6/10 1963