

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER, SALEM, OREGON 97310

WATER WELL REPORT

3 1966 STATE OF OREGON (Please type or print)

MAR 19 1966

State Well No. 4/1w-12 N(2) State Permit No.

G-3571

(1) OWNER:

Name Geolge Wiederhold Address Aurora, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 12 T. 4S R. 1W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 74 ft. Gage 1/4"

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [] Yes [x] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 26 ft. below land surface Date 5/27/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? driller Yield: 140 gal./min. with 40 ft. drawdown after 6 hrs.

(12) WELL LOG:

Diameter of well below casing Depth drilled 74 ft. Depth of completed well 74 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Soil (0-3), Brown clay (3-8), Brown sandy clay (8-58), Blue sandy clay (58-65), Broken gravel (65-74)

Work started May 24 1966 Completed May 27 1966 Date well drilling machine moved off of well May 27 1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller (Person, firm or corporation) Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 26

[Signed] John T. Miller (Water Well Contractor)

Contractor's License No. 277 Date May 28 1966