

MARI... 4726

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT

MAY 10 1965 STATE OF OREGON (Please type or print)

State Well No. 6/2w-34

State Permit No.

(1) OWNER:

Name DALE HERIGSTAD Address 4712 SILVERTON RD N.E. SALEM ORE.

(2) LOCATION OF WELL:

County MARIOTT Driller's well number NE 1/4 1/4 Section 34 T. 6S R. 2W. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic X Industrial Municipal Irrigation X Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 105 ft. Gage 17.02

(7) PERFORATIONS:

Perforated? X Yes No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? X Yes No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE Depth of seal 60 ft. Was a packer used? YES Diameter of well bore to bottom of seal 9 in. Were any loose strata cemented off? NO Depth Was a drive shoe used? YES NO Was well gravel packed? YES NO Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? YES NO Type of water? SANDY Depth of strata 86' TO 100' Method of sealing strata off CASEP

(10) WATER LEVELS:

Static level 44 ft. below land surface Date 5-6-65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? X Yes No If yes, by whom? STETTLER SUPPLY Yield: 105 gal./min. with 55 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 105 ft. Depth of completed well 105 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOPSOIL, CLAY YELLOW SILTY, SAND FINE, CONGLOMERATE, GRAVEL + SAND, SAND FINE BROWN, GRAVEL 1".

Work started 5-3-65 Completed 5-6-1965 Date well drilling machine moved off of well 5-6-1965

(13) PUMP:

Manufacturer's Name Type: SUBMERSIBLE H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS (Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM, O.

Drilling Machine Operator's License No. 187

[Signed] J. A. Sneed (Water Well Contractor)

Contractor's License No. 6 Date 5-6-1965