

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT MAR 1969

STATE OF OREGON

4755

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

State Well No. 6/2w-356c

State Permit No. G 5240

(1) OWNER: Jensen Bros Rt2 Silverton, Oreg

(11) LOCATION OF WELL: Marion County Driller's well number

(2) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon []

Bearing and distance from section or subdivision corner 1800ft S. & 500 ft. E. of N*W. Cor Sec 35 T. 6, S. - R. 2x2W.

(3) TYPE OF WELL: Rotary [x] Cable [] Dug []

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(12) WELL LOG: Diameter of well below casing none Depth drilled 119 ft. Depth of completed well 119 ft.

CASING INSTALLED: 24" Diam. from 0 ft. to 36 ft. Gage .250 30" Diam. from 0 ft. to 89 ft. Gage .250

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated.

PERFORATIONS: Perforated? [] Yes [x] No. Type of perforator used Size of perforations in. by in.

Table with columns: MATERIAL, From, To, SWL. Rows include Topsoil brn., Clay brn., Clay grey, Fine sand grey, Clay grey sandy, Packed sand fine grey blkx, Clay grey hard, Packed sand fine grey, Clay brn. hard, Fine sand brn., Course conglom. brn., Med sand brn., Course sand & gravel W.B., Course conglom. W.B.

(7) SCREENS: Well screen installed? [x] Yes [] No Manufacturer's Name Johnson Type Irrigator Model No. 100

(8) WATER LEVEL: Completed well. Static level 67 ft. below land surface Date 8/7

(9) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Driller

Work started 7/7 1969 Completed 8/7 1969 Date well drilling machine moved off of well 8/27 1969

Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] C.E. Stadel Date 9/23, 1969

(10) CONSTRUCTION: Well seal—Material used Cement Depth of seal 36 ft. Diameter of well bore to bottom of seal 32 in. 22" to 119"

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME R. Stadel & Sons Address Silverton, Oreg. [Signed] Paul R. Stadel (Water Well Contractor) Contractor's License No. 296 Date 9/23, 1969