

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON-97310 within 30 days from the date of well completion.

RECEIVED
OCT 13 1969
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

475
MARI...

State Well No. 6/2W-35ab

State Permit No. G5246

(1) OWNER:

Name Jensen Bros.
Address Rt. 2 Box 195
Silverton, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

123/4" Diam. from 140 ft. to 168 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations 3/8 in. by 2 in.
768 perforations from 107 ft. to 138 ft.
324 perforations from 138 ft. to 165 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Type Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 48 ft. below land surface Date 10/7/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? Yes No If yes, by whom? Stettler
Yield: 520 gal./min. with 18 ft. drawdown after 1 hrs.
" 800 " " 43 " " 2 1/2 "
" 920 " " 55 " " 2 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Clay
Depth of seal 24 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 6/2W-35M
1/4 1/4 Section T. R. W.M. #

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 168 ft. Depth of completed well 168 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	2	
Yellow clay	2	25	
Blue clay	25	55	
Brown clay	55	70	
Brown sand & clay	70	75	
Brown sand	75	88	
Brown sand & gravel with clay	88	105	
Loose sand & gravel	105	138	
Gravel with clay	138	168	

Work started 9/15 19 69 Completed 10/7/69 19

Date well drilling machine moved off of well 10/7/69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harry A. Robinson Date 10/9, 19 69
(Drilling Machine Operator)

Drilling Machine Operator's License No. 63

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson
(Person, firm or corporation) (Type or print)

Address 2214 Front St NE Salem, Ore.

[Signed] Harry A. Robinson
(Water Well Contractor)

Contractor's License No. 22 Date 10/9/69, 19.....