

## NOTICE TO WATER WELL CONTRACTOR

The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date  
of well completion.

## WATER WELL REPORT

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

State Well No.

State Permit No.

G 5416

## (1) OWNER:

Name Dryden LaFollette  
Address Box 94, Newberg, Oregon

## (2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:

Rotary ☐ Driven ☐  
Cable ☒ Jetted ☐  
Dug ☐ Bored ☐

## (4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☒ Test Well ☐ Other ☐

## (5) CASING INSTALLED:

Threaded ☐ Welded ☒  
12" Diam. from 0 ft. to 65 ft. Gage 350  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

## (6) PERFORATIONS:

Perforated? ☒ Yes ☐ No.Type of perforator used Mills

Size of perforations 3 1/2 in. by 38 in.  
864 perforations from 32 ft. to 63 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

## (7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

## (8) WATER LEVEL: Completed well.

Static level 15 ft. below land surface Date \_\_\_\_\_

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

## (9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Stollens  
380 gal./min. with 45 ft. drawdown after 1 hrs.

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

## (10) CONSTRUCTION:

Well seal—Material used Quartz clay  
Depth of seal 20 ft.

Diameter of well bore to bottom of seal 16 in.Were any loose strata cemented off? ☐ Yes ☒ No Depth \_\_\_\_\_Was a drive shoe used? ☒ Yes ☐ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

Was well gravel packed? ☐ Yes ☒ No Size of gravel: \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

## (11) LOCATION OF WELL:

County Mason Driller's well number \_\_\_\_\_  
1/4 1/4 Section 34 T. 5 R. 3 W.M.

Bearing and distance from section or subdivision corner \_\_\_\_\_

## (12) WELL LOG:

Diameter of well below casing \_\_\_\_\_

Depth drilled 65 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	5	
Blue clay	5	25	
Brown sand	25	30	
Gravel	30	65	

Work started Dec. 15 1967 Completed Feb. 6 1968Date well drilling machine moved off of well Jan. 15 1968

## Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Lervaco Date Feb. 6 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 179

## Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. F. Terrell  
(Person, firm or corporation) (Type or print)

Address RT #1, Box 57, Gerwin, Ore.

[Signed] Mrs. Zona D. Terrell  
(Water Well Contractor)

Contractor's License No. 760 Date Feb. 6 1968

(USE ADDITIONAL SHEETS IF NECESSARY)