

4786
MAR 1963

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 6/34-2

State Permit No.

RECEIVED
MAY 20 1963
STATE ENGINEER
SALEM OREGON

(1) OWNER:

Name **JOE RYAN**
Address **RT. 1 BOX 104
GERVAIS, OREGON.**

(2) LOCATION OF WELL:

County **MARION** Driller's well number **826**
1/4 Section T. **6** R. **S R 3** W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from **TOP** ft. to **40** ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used **MILLS**
Size of perforations in. by in.
230 perforations from **16** ft. to **39** ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal **CEMENT & PUTTLE CLAY**
Depth of seal **18** ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level **10** ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? **DRILLER**
Yield: **600** gal./min. with **15** ft. drawdown after **5** hrs.
" **550** " **13** " **5** "
" **450** " **8** " **5** "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled **40** ft. Depth of completed well **40** ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	4
SANDY SILTY	4	12
SAND & GRAVEL	12	40

BAL. OF PUMPING ON WELL
400 G.P.M. 7 D.D. 5 HRS.
330 G.P.M. 4 D.D. 5 HRS.

Work started **MAY 12 1963** Completed **MAY 15 1963**
Date well drilling machine moved off of well **MAY 15 1963**

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME **WILLAMETTE DRILLING CO.**
(Person, firm or corporation) (Type or print)
Address **RT. 2 BOX 276 SALEM, OREGON.**

Drilling Machine Operator's License No. **141**

[Signed] **Emil O. Beier**
(Water Well Contractor)

Contractor's License No. **2** Date **MAY 15 1963**