NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED SEP 29 1965 STATE ENGINEER SALEM OREGON

MAR 4835

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 6/3w-10K

State Permit No. G-3858

(1) OWNER:

Name Mr. Glen Walton

Address Route 2, Box 119
Salem, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number

¼ ¼ Section 10 T. 6S R. 3W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

12" Diam. from ft. to ft. Gage ¼"
" Diam. from 1 ft. above groundlevel to
" Diam. from 40 ft. below groundlevel

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used Cutting torch

Size of perforations ½ in. by 8 in.

perforations from ft. to ft.
53 perforations from 29 ft. to 38 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 15 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: #2 round
Gravel placed from 18 ft. to 40 ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 26 ft. below land surface Date 9/10/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Bailer test 45 gal./min. with NO drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water 50° Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well below casing

Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	4'
Brown clay	4'	8'
Med. Gravel & Clay	8'	26'
Sand & gravel (water bearing)	26'	40'

Work started Sept. 9, 1965 Completed Sept. 11, 1965

Date well drilling machine moved off of well Sept. 13, 1965

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ART CLINTON WELL DRILLING CO.
(Person, firm or corporation) (Type or print)

Address Route 1, Box 2, Independence, Oregon 97351

Drilling Machine Operator's License No. 34

[Signed] Art Clinton
(Water Well Contractor)

Contractor's License No. 14 Date Sept. 23, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)