

MARK 4836

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 6/3W-10M State Permit No.

APR 9 1963

G 2413

(1) OWNER:

Name Mr. James E. Whelan Address Stanfield, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 10-15 T. 6 R. 3 W W.M. Bearing and distance from section or subdivision corner

TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

12" Diam. from 1 ft. above ground level to 44 ft. depth

(7) PERFORATIONS:

Perforated? [X] Yes [] No

Type of perforator used Cutting torch Size of perforations 4 in. by 8 in. 82 perforations from 26 ft. to 42 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes [] No [X] Depth Was a drive shoe used? Yes [] No [X] Was well gravel packed? Yes [] No [X] Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes [] No [X] Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 16 ft. below land surface Date 3-14-63 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Stettler Yield: 610 gal./min. with 3 ft. drawdown after 1 hrs. Baller test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 54 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing ----- Depth drilled 45 ft. Depth of completed well 45 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Willamette soil (0-5), Brown Clay (5-10), Medium gravel (10-22), Large gravel - water bearing (22-45)

Work started March 13 1963 Completed March 16 1963 Date well drilling machine moved off of well March 19 1963

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Art Clinton Well Drilling Co. (Person, firm or corporation) (Type or print) Address Rt. 1, Box 2, Independence, Oregon

Drilling Machine Operator's License No. 34

[Signed] Art Clinton (Water Well Contractor)

Contractor's License No. 14 Date March 19, 1963