

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

MAR 4 888

State Well No. 65/3W-13

State Permit No.

WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER:

Name William S. Downer Address 9700 River Rd. NE Brooks, Oregon 97305

(10) LOCATION OF WELL:

County Marion Driller's well number X 2161 1/4 1/4 Section 13 T. 6S R. 3W W.M.

(2) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandon If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary X Driven Cable Jettied Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation X Test Well Other

CASING INSTALLED:

10" Diam. from top ft. to 163 ft. Gage 250 Threaded Welded

(11) WATER LEVEL: Completed well.

Depth at which water was first found 99 ft. Static level 46 ft. below land surface. Date 7/7/78 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing Depth drilled 163 ft. Depth of completed well 163 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Topsoil, Brown Clay, Blue Clay, Brown Sand and Gravel with Brown Clay, Brown Sand and Gravel.

Work started 7/6/78 19 Completed 7/7/78 19 Date well drilling machine moved off of well 7/8/78 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas L. Davis Date 7/8/78 19 (Drilling Machine Operator)

Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Willamette Drilling Co. (Person, firm or corporation) (Type or print)

Address 1450 Barnick Rd. NE Salem, OR 97303

[Signed] Dallas L. Davis (Water Well Contractor)

Contractor's License No. 561 Date 7/8/78 19

PERFORATIONS:

Perforated? X Yes No. Type of perforator used Mills Knife Perforator Size of perforations 3/8 in. by 2 1/2 in. 800 perforations from 110 ft. to 160 ft.

(7) SCREENS:

Well screen installed? Yes No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? X Yes No If yes, by whom? driller Yield: 650 gal./min. with 5 ft. drawdown after 2 hrs.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 17 1/2 in. Diameter of well bore below seal 10 in. Number of sacks of cement used in well seal 24 sacks How was cement grout placed? poured in from the top

Was a drive shoe used? X Yes No Plugs Size: location ft. Did any strata contain unusable water? Yes No Type of water? depth of strata Method of sealing strata off Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft.