

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

4897
MARY

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
MAY 17 1968
STATE ENGINEER
SALEM, OREGON

State Well No. 6/3w-13

Permit No. _____

(1) OWNER:

Name Homer Goulet
Address 8550 Wheatland Rd., NE Salem, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from top ft. to 180 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
500 perforations from 90 ft. to 135 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 5-2-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 400 gal./min. with 30 ft. drawdown after 12 hrs.
500 " " 38 " " 12 "
" 600 " " 45 " " 12 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings & Puddle Clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1306
1/4 1/4 Section 13 T. 6 R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 180 ft. Depth of completed well 180 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown Clay	2	45	
Gray Clay	45	60	
Black sand & gray clay	60	80	
Black sand & gravel	80	85	
Gray Clay	85	90	
Brown Sand & Gravel	90	100	
Brown sand & gravel	100	135	
Gray Clay	135	165	
Black Sand	165	175	
Black sand & gravel	175	180	40

Work started April 8, 1968 Completed May 3, 68 19
Date well drilling machine moved off of well May 3, 68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Lyle Beckwith Date May 3, 68
(Drilling Machine Operator)

Drilling Machine Operator's License No. 151

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 7641 35th ave., NE Salem, Oregon 97303

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date May 4, 1968, 19