NOTICE TO WATER WELL CONTRACTOR IN The original and first copy of this report are to be filed with the APR 3 1968

E WATER WELL REPORT

STATE OF OREGON STATE OF OREGON STATE ENGINEER, SALEM OREGON 57310 NGINEER (Please type or print) within 30 days from the date of the date of well completion. SALEM OREGON (Do not write above this line)

State	Well	No.	6/	3	w	 j	3	bd	q	
State	*** ***	1.0.	7	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,						

	State Permit No.	************************************
5089		

1) OWNER:	(11) LOCATION OF WELL:				
ame William Downer	County Marion Driller's well number 1297				
ddress 9700 River Road NE Salem, Oregon	¼ ¼ Section 13 т. 6S	r. 3W	W.M		
O TYPE OF WORK (1 1)	Bearing and distance from section or subdivision	n corner			
2) TYPE OF WORK (check):					
ew Well Deepening Reconditioning Abandon Abandon					
abandonment, describe material and procedure in Item 12.					
3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well	below casing			
able . Jetted . Domestic . industrial . Municipal .	Depth drilled]40 ft. Depth of compl	eted well 14	O ft		
ug 🗌 Bored 🗌 Irrigation 🏗 Test Well 🗍 Other 📋	Formation: Describe color, texture, grain size	and structure of	materials		
CASING INSTALLED: Threaded Welded W	and show thickness and nature of each stratu with at least one entry for each change of form	nation. Report ea	ch chang		
10" Diam. from top	in position of Static Water Level as drilling pro	oceeds. Note dril	ling rates		
" Diam. from ft. to ft. Gage	MATERIAL	From To	SWL		
" Diam. fromft. toft. Gage	Top Soil	0 2	;		
PERFORATIONS: Perforated? Ty Yes No.	Brown Clay	2 40			
Type of perforator used Mills	Blue Clay	40 75	1		
tize of perforations 2 in. by 3/8 in.	Black sand & Gravel	75 85			
510 perforations from 85 ft. to 139 ft.	Brown sand włayx gravel		i i		
perforations from ft. to ft.	Brown sand clay & gravel	 100 14 0	40		
perforations from ft. to ft.					
perforations from ft. to ft.					
perforations from ft. to ft.					
7) CODEENS.					
7) SCREENS: Well screen installed? Yes No					
Manufacturer's Name		-			
Diam. Slot size Set from ft. to ft.			-		
Diam. Slot size Set from ft. to ft.					
(8) WATER LEVEL: Completed well.					
(9) WELL TESTS: Drawdown is amount water level is lowered below static level					
Was a pump test made? de Yes 🗆 No If yes, by whom? كار المراكة المرا	Work started March 11.1968 Comple	bod American	192		
d: 400 gal./min. with 43 ft. drawdown after 4 hrs.			1961 58 19		
500 " 45 " 4 "	Date well drilling machine moved off of well	ADELL I.	00 19		
n u n n	Drilling Machine Operator's Certification	:	35 -4.		
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my crials used and information reported abo	ove are true to	my be		
Artesian flow g.p.m. Date	knowledge and belief.				
Temperature of water 55 Was a chemical analysis made? Yes No	[Signed] The Dechtron	Date 4-2-9	38, 19		
	(Drilling Machine Operator)				
(10) CONSTRUCTION:	Drilling Machine Operator's License No.	151			
well seal—Material useDrill cuttings Puddle clay	Water Well Contractor's Certification:				
Depth of seal	This well was drilled under my juris	diction and this	report		
Diameter of well bore to bottom of seal	true to the best of my knowledge and be	lief.			
Were any loose strata cemented off? Tyes I No Depth	NAME WILLAMETTE DRILLING	1 COMPANY	nt)		
Was a drive shoe used? A Yes No	(Person, firm or corporation)	(Type or pri			
Did any strata contain unusable water? Yes No	Address 7641 35th Ave. NE S	Salem, Or	egon -		
Type of water? depth of strata	() () () () () () () () () ()				
Method of sealing strata off	[Signed] (Water Well Contr	actor)			
Was well gravel packed? ☐ Yes 🏋 No Size of gravel:		j	4		
and the second s	Contractor's License No	4-2-68			