

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON STATE ENGINEER SALEM OREGON

(Please type or print) State Well No. SALEM OREGON State Permit No.

RECEIVED AUG 2 1973

65/3W-14

49.00 MAR 1973

(1) OWNER:

Name Kenneth Moisan Address 9155 Wheatland Road NE Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(5) CASING INSTALLED:

Threaded [ ] Welded [x] 10" Diam. from top ft. to 40 ft. Gage 250

(6) PERFORATIONS:

Perforated? [x] Yes [ ] No. Type of perforator used Mills Size of perforations 7/16 in. by 2 3/4 in. 200 perforations from 24 ft. to 40 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [x] No If yes, by whom? gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Well seal—Material used Cement Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 14 in. Diameter of well bore below seal 10 in. Number of sacks of cement used in well seal 10 sacks

(10) LOCATION OF WELL:

County Marion Driller's well number 1756 1/4 Section 14 T. 6S R. 3W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 19 ft. Static level 20 ft. below land surface. Date 7-30-73 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include Brown top Soil, Brown silty Clay, Brown muddy Sand, Brown sand and gravel.

Work started July 27, 19 73 Completed July 30, 73 Date well drilling machine moved off of well July 30, 1973 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 7-31-73, 19 Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name WILLAMETTE DRILLING COMPANY (Person, firm or corporation) (Type or print) Address 7641 35th Ave. NE Salem, Oregon [Signed] [Signature] (Water Well Contractor) Contractor's License No. 2 Date 7-31-73, 19