

1171
4914

(1) OWNER:

Name FLOYD HERROLD
Address RT-2 Box 139
SALEM ORE

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
NW 1/4 SW 1/4 Section 14 T. 6S R. 3W W.M.
Bearing and distance from section or subdivision corner
350 ft. south e 1090 ft. east from Wly cor
ner of Section 14.

(3) TYPE OF WORK (check): OLD WELL

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded 1"
8" Diam. from 29' ft. to 29' ft. Gage 4'
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS TYPE
SIZE of perforations 5" in. by 2 1/2" in.
280 perforations from 18' ft. to 28' ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 6" ft.
Material used in seal— PUMP
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off BACK FILL

(10) WATER LEVELS:

Static level 8' ft. below land surface Date 1958
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level SNEED BROS
Was a pump test made? Yes No If yes, by whom?
Yield: 300 gal./min. with 6' ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8" 1-D inches.
Depth drilled 29' ft. Depth of completed well 29' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	4'	4'
CLAY-SANDY-YELLOW	5'	9'
SAND MEDIUM-	3'	12'
CEMENTED GRAVEL	5'	17'
WATER GRAVEL H 4"	12'	29'

CASING EQUIPPED WITH
HEAVY COUPLING FOR SHOE

Work started 1958 Completed 1958

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J-A. SNEED + SONS
(Person, firm, or corporation) (Type or print)

Address 2505 BROOKS ST SALEM ORE

Driller's well number _____

[Signed] J. A. Sneed
(Well Driller)

License No. B Date 2-20, 1958