

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

JUN 25 1968 STATE OF OREGON

4922  
MAR 1968

State Well No. 6/3w-15

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON

(Do not write above this line)

State Permit No.

**(1) OWNER:**

Name OTTO T. PAULSON  
Address 9230 RIVER RD. N.E. SALEM ORE 97303

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
8" Diam. from 0 ft. to 135 ft. Gage 1/2"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used MILLS  
Size of perforations 7/16 in. by 2 1/2 in.  
100 perforations from 121 ft. to 128 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 31 ft. below land surface Date 6-20-68  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Gal. per min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 54 gal./min. with 4 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 57° Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used BENTONITE  
Depth of seal 40 ft.  
Diameter of well bore to bottom of seal 12" in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? SANDY depth of strata 65' to 80'  
Method of sealing strata off CASED 86' to 93'  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County MARION Driller's well number  
1/4 NE 1/4 Section 15 T. 6S R. 3W W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 8"  
Depth drilled 135' ft. Depth of completed well 135' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW	2	44	
CLAY BLUE SILTY	44	65	
SAND BLACK FINE	65	80	
CLAY BLUE STICKY	80	84 1/2	
CONGLOMERATE	84 1/2	86	
SAND - BLACK FINE	86	93	28'
CLAY BLUE STICKY	93	99	
SAND BROWN - MED.	99	108	28'
CONGLOMERATE - BROWN	108	121	
GRAVEL - COARSE	121	123	31'
CONGLOMERATE YELLOW	123	130	
CONGLOMERATE BLUE	130	131	
SAND BROWN - FINE	131	134	31'
CONGLOMERATE BLUE	134	135	

Work started 6-17 1968 Completed 6-20 1968  
Date well drilling machine moved off of well 6-20-1968

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R. J. Sneed Date 6-20, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. R. SNEED & SONS  
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM ORE. 97303

[Signed] R. J. Sneed  
(Water Well Contractor)

Contractor's License No. 6 Date 6-20, 1968