

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT MAY 24 1965 STATE ENGINEER SALEM OREGON

4938 MAR 1965

State Well No. 6/3w-15M State Permit No.

(1) OWNER:

Name CAPITOL FARMS INC. Address RT. 2 BOX III SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I022 1/4 Section I6 T. 6 S R. 3 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation X Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded X 10" Diam. from TOP ft. to 100 ft. Gage 250

(7) PERFORATIONS:

Perforated? X Yes No Type of perforator used MILLS Size of perforations 2 in. by 3/8 in. 671 perforations from 25 ft. to 95 ft.

(8) SCREENS:

Well screen installed? Yes X No Manufacturer's Name Model No. Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes X No Was well gravel packed? Yes X No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 5/12/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? X Yes No If yes, by whom? DRILLER Yield: 600 gal./min. with 18 ft. drawdown after 20 hrs. 500 8 20

(12) WELL LOG:

Diameter of well below casing Depth drilled 100 ft. Depth of completed well 100 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: TOP SOIL (0-3), BROWN CLAY (3-20), BROWN SAND & GRAVEL (20-25), BLACK SAND & FEW ROCKS & WOOD (25-80), BLUE CLAY (80-100)

Work started MAY 1 19 65 Completed MAY 12 1965 Date well drilling machine moved off of well MAY 12 1965 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 151

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date MAY 12 1965 9