

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

State Well No. 6/3w-1591

State Permit No. Q2203

(1) OWNER:

Name J. E. Whelan
Address Route 2, Box 105 Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any - 1/4 Section 15 T. 6 R. 3 W.W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from top ft. to 47 ft. Gage 5/16
Threaded [X] Welded []

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Cutting torch
SIZE of perforations 1/4 in. by 8 in.
114 perforations from 28 ft. to 47 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [X] Yes [] No Size of gravel: No. 2
Gravel placed from top ft. to bottom ft.
Was a surface seal provided? [] Yes [] No To what depth? ft.
Material used in seal -
Did any strata contain unusable water? [X] Yes [] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 23 ft. below land surface Date 4-27-61
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] J. E. Whelan Date 6-7, 1961 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Hettler, Suppl
Yield: 450 gal./min. with 19 ft. drawdown after hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 47 ft. Depth of completed well 47 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: River Bottom Loam (0-2), Brown Clay (2-23), Sand, gravel & boulders (23-47)

Work started 4-27-61 19 Completed 5-1-61 19

(13) PUMP:

Manufacturer's Name Berkeley
Type: Turbine H.P. 15

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Art Clinton (Person, firm, or corporation) (Type or print)

Address Rt. 1, Box 2, Independence, Oregon

Driller's well number 61-#5

[Signed] Art Clinton (Well Driller)

License No. 14 Date 5-1-61 19