

KERR HOP RANCH.

MARI... 4943

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT RECEIVED JUN 12 1967 JUN 27 1967 State Well No. 6/3w-16 State Permit No.

(1) OWNER:

Name ROGER KERR, Address Rt. 2 SALEM OREG.

(2) LOCATION OF WELL:

County MARION Driller's well number 1/4 Section 16 T. 6S R. 3W. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 100' ft. Gage #1 Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used MILLS Size of perforations 3/8" in. by 3" in. 500 perforations from 29' ft. to 54' ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE Depth of seal 22' ft. Was a packer used? yes Diameter of well bore to bottom of seal 14" in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 18' ft. below land surface Date 6-2-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? Yield: 750 gal./min. with 14 ft. drawdown after 1 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 52° Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 10" Depth drilled 100' ft. Depth of completed well 100' ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOPSOIL, SILT-YELLOW COLOR, SANDBROWN FINE, CONGLOMERATE, GRAVEL 3", CONGLOMERATE-YELLOW, CONGLOMERATE BLUE, CLAY BLUE STICKY, CLAY BLUE SANDY, CLAY BLUE STICKY, CLAYSTONE GRAY FIRM.

Work started 5-31-1967 Completed 6-2-1967 Date well drilling machine moved off of well 6-2-1967

(13) PUMP:

Manufacturer's Name FAIR BANKS MORSE Type: TURBINE H.P. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS (Person, firm or corporation) (Type or print) Address 3910 SILVERTON RD. SALEM OREG. 97303 Drilling Machine Operator's License No. 187 Contractor's License No. 6 Date 6-2-1967 [Signed] B. F. Sneed (Water Well Contractor)