

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

MARION 4-9-76
WATER WELL REPORT RECEIVED

STATE OF OREGON
(Please type or print)

MAY - 2 1977

State Well No. 65/3W 22C

(Do not write above this line)
WATER RESOURCES DEPARTMENT
SALEM, OREGON Permit No. _____

(1) OWNER:

Name Dale Turnidge
Address 1709 Buxter Rd SE
Salem, OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(10) LOCATION OF WELL:

County Marion Driller's well number
SW 1/4 SW 1/4 Section 22 T. 6, S R. 3, W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 27 ft.
Static level 27 ft. below land surface. Date 4-29-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 52 ft. Depth of completed well 52 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Fine Brown Sand #5m gravel	0	17	
Fine to Coarse Brown Sand and Brown Clay	17	26	
Loose, Small to Med. Gravel and Br. Sand	26	36	27'
Med to Large Gravel and Br. Sand	36	52	

Work started 4-18 1977 Completed 4-24 1977
Date well drilling machine moved off of well 4-29 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Michael Waldrop Date 4/29 1977
(Drilling Machine Operator)

Drilling Machine Operator's License No. 873

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MILLER & WEST DRILLING
(Person, firm or corporation) (Type or print)

Address 5875 GAIN RD. SE

[Signed] Michael Waldrop
(Water Well Contractor)

Contractor's License No. 633 Date 4/29 1977

CASING INSTALLED:

Threaded Welded
2" Diam. from +1 ft. to 52 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Torch
Size of perforations 1/2 in. by 6 in.
80 perforations from 31 ft. to 51 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stettlers
600 gal./min. with 3 ft. drawdown after 6 hrs.
" " " "
" " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used portland cement
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 51 sacks
How was cement grout placed? Cement was poured in as surface casing was removed
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.