NOTICE TO WATER WELL CONTRACTOR MAR 26 1369 WATER WELL REPORT of this report are to be MAR 26 1369 WATER WELL REPORT filed with the STATE OF OREGON STATE ENGINEER, SALEM, OREGON 97310 CIVIL STATE type or print within 30 days from the date. L.M. OREGON Do not write above this line) of well completion.

State Well No.

State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:
Name R.H. Clark & Son Inc.	County Marion Driller's well number 69_1
Address 9775 River Rd. N.E. Salem, Ore.	14 14 Section 22 T. 68 R. 3W W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	1500' East & 1000' North from
New Well Deepening □ Reconditioning □ Abandon □	section corner 22
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Rotary	Depth drilled 80 ft. Depth of completed well 80 ft.
Dug Bored Irrigation Tart Well Other	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change
18 " Diam. from 0 ft. to 30 ft. Gage • 250	in position of Static Water Level as drilling proceeds. Note drilling rates.
ft. Gageft.	MATERIAL From To SWL
ft. to ft. Gage	Sandy Clay-Brown 0 2
PERFORATIONS: Perforated? 77 Yes No.	Sandy Lome-Brown 2 17
	Clav-Sand & Gravel 17 22
Type of perforation used cutting torch Size of perforations 3/8 in. by 6 in.	Gravel-Med. Water hearing 22 38 20
724 67 %0	Sand & Gravel-Med.Cemented
	with Clay-Brown 38 56
perforations from ft. to ft	Gravel-Med. & Large 56 79 22
perforations from ft. to ft.	Clay-Blue 79 80
perforations from ft. to ft.	
· · · · · · · · · · · · · · · · · · ·	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	
Manufacturer's Name	
Type Model No.	
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	
Didni	
(8) WATER LEVEL: Completed well.	
Static level 22 ft. below land surface Date 3/22/69) — — — — — — — — — — — — — — — — — — —
esian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ▼ Yes □ No If yes, by whom?]ri]]er	Work started 3/8 1969 Completed 3/22 1969
yield 900-1000gal./min. with 23 ft. drawdown after 4 hrs.	
Test by Air Compresser " "	Date well drilling machine moved off of well 3/22 1969
" " " " " " " " " " " " " " " " " " "	Drilling Machine Operator's Certification:
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No	[Signed] Walter Macu Date 3/22, 1969
(10) CONSTRUCTION:	Drilling Machine Operator's License No. 595
Well seal-Material used Bentonite	
Depth of sealft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off? Yes You Depth	
Was a drive shoe used? Yes No	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	Address 16675 S.E. McLaughlin, Milw., Ore.
Type of water? depth of strata	9.7 14 MM
Method of sealing strata off	[Signed] Waller 11 acl
Was well gravel packed? ☐ Yes 📉 No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 497 Date 3/22 1969