NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

SOON WATER WELL REPORTED 2 9 1974 State Well No. 65/3W-23 RECEIVED

STATE OF OREGON
(Please type or print) STATE ENGINEER
(Do not write above this line ALEM, OREGON

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Lloyd Weigel	County Merion Driller's well number 1864
Address 4690 River Road NE Salem, Oregon	1/4 1/4 Section 23 T. 6S R. 3W W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 🖸 Deepening 🗍 Reconditioning 🗋 Abandon 🖺	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 98 ft.
Rotary Driven Domestic Dindustrial Municipal Domestic Dindustrial Municipal Domestic	
Cable	1 ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) (
	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded \( \Bar{\pi} \) Welded \( \Bar{\pi} \)	(12) WELL LOG: Diameter of well below casing
6 "Diam from top ft. to 105 ft. Gage 250	Depth drilled 105 ft. Depth of completed well 105 ft.
ft. Gage	
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated?   Yes   Fl No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
(5) FERFORATIONS: Perforated?  Yes  No.  Type of perforator used	
	MATERIAL From To SWL
Size of perforations in. by in.	Top Soil 0 3
perforations fromft. toft.	Brown Clay 5 74
perforations fromft. toft.	Brown cemented Gravel 74 93
perforations from	Loose Brown Sand and gravel 98 105
(7) SCREENS: Well screen installed? ☐ Yes I No	
Manufacturer's Name	
Type Model No.	
Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? [] Yes [] No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
n n	
n " " " " " " " " " " " " " " " " " " "	
Bailer test 25 gal./min. with 5 ft. drawdown after 1 hrs.	· · · · · · · · · · · · · · · · · · ·
Artesian flow g.p.m.	
perature of water Depth artesian flow encounteredft.	W
	Work started 10-4-74 19 Completed 10-10-74 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well 10-19-74 19
Well seal-Material used <u>Cement</u>	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision.  Materials used and information reported above are true to my
Diameter of well bore to bottom of seal10in.	best knowledge and belief.
Diameter of well bore below seal	[Signed] Mark D Buer Date 10-10-74 19
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No811
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals.	true to the best of my knowledge and belief.
Was a drive shoe used? Ne yes No Plugs Size: location ft.	Name WILLAMETTE DRILLING COMPANY
Did any strata contain unusable water? ☐ Yes ☒ No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 7641 35th Ave. NE Salem, Oregon 57303
Method of sealing strata off	[Signed] My Clar
Was well gravel packed? [] Yes [] No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No2 Date