The original and first copy of this report are to be filed with the MAR 6 1970 STATE OF OREGON

STATE ENGINEER, SALEM, OREGINATE ENGINEER type or print) within 30 days from the date ENGINDE ENGINEER type or print) SALEM. ORLCON

State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:	_
Name John Wiensz	County 35 * Dellian's small sussels	
Address 4641 Nandale Drive NE Salem, Oregon .	1/ 1/ 0 1/ 0 7	. M .
	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	- earling dried desiration of subdivision contex	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐		_
If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing	
Rotary	Donth drilled Eo. # Donth of and I I	
Dug ☐ Bored ☐ Irrigation 🔀 Test Well ☐ Other ☐	34	ft.
CASING INSTALLED: Threaded □ Welded ₩	Formation: Describe color, texture, grain size and structure of materia and show thickness and nature of each stratum and aquifer penetrate	eđ,
8 " Diam. fromtop	with at least one entry for each change of formation. Report each chan in position of Static Water Level as drilling proceeds. Note drilling rat	ige
" Diam, fromft. toft. Gage		
"Diam, fromft. toft. Gage		_
22) DEDEOD A MICONG	Top Soil 0 3	
	Brown clay 3 12	 ,
pe of perforator used Mills	Brown sand and gravel 12 52	
Size of perforations 2 in. by 3/8 in.	100 100 100 100 100 100 100 100 100 100	
perforations fromft. toft.		
perforations fromtt. totttt.		· .,
perforations fromft. toft.		
	*	-
(7) SCREENS: Well screen installed? ☐ Yes ☑ No		
Manufacturer's Name		
Type Model No		
Diam. Slot size Set from ft. to ft. Diam. Slot size ft. to ft.		
(8) WATER LEVEL: Completed well.		
Static level 15 ft. below land surface Date 2-25-70		ir .
sian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is		_
lowered below static level	4	
Was a pump test made? Tyes \(\text{No If yes, by whom? Driller} \) Yield: 270 \(\text{gal./min. with 20 ft drawdown after \(\text{Arawdown after } \)	Work started 2-18-70 19 Completed 2-25-70 19	
the state of the s	2-25-70	<u> </u>
4	/=/B=/()	
400 " 25 " 4 "	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mat	
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my be	e- est
Artesian flow g.p.m. Date	knowledge and belief.	
Femperature of water Was a chemical analysis made? ☐ Yes ☐ No	[Signed] Orilling Machine Operator) Date 2-26-70, 19	****
(10) CONSTRUCTION:		
Well seal-Material used Cement and Puddle Clay	Drilling Machine Operator's License No151	-
Depth of seal	Water Well Contractor's Certification:	
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report	is
Were any loose strata cemented off? 🗌 Yes 🙀 No Depth	true to the best of my knowledge and belief.	
Was a drive shoe used? ⊠ Yes □ No	NAME WILLAMETTE DRILLING COMPANY (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water? 🔲 Yes 🖾 No		
Type of water? depth of strata	Address 7641 35th Ave. NE Salem Oregon 97303	
Method of sealing strata off	[Signed] CML () (SIJON)	
Was well gravel packed? Yes No Size of gravel:	[Signed] (Water Well Contractor)	
Gravel placed from ft. to ft.	Contractor's License No. 2 Date 2-26-70 19	
	Date	