

MARION...5047

RECEIVED JUN 12 1964

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON WATER WELL REPORT

(Please type or print)

G-2199

State Well No. 6/3w-23ddc

State Permit No.

(1) OWNER:

Name JOE OPPEK Address 7555 O'NEILL RD. N.E. SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 923 1/4 Section 23 T. 6 R. 3 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

6" Diam. from TOP ft. to 86 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No

Type of perforator used MILLS

Size of perforations 1/2 in. by 1 in. 90 perforations from 75 ft. to 85 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUTTLE CLAY Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 50 ft. below land surface Date 5/27/64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

Baller test 40 gal./min. with 10 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 86 ft. Depth of completed well 86 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, BROWN SILTY, GRAY SILTY, BLACK SAND, BROWN SAND & GRAVEL.

Work started MAY 21 19 64 Completed MAY 27 64 Date well drilling machine moved off of well MAY 27 19 64

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO. (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 151

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date 5/27/64, 19