

RECEIVED

MARI 50928

SEP 25 1996

# ~~802084~~

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

(START CARD) # 85410

Instructions for completing this report are on the last page of this form.

WATER RESOURCES DEPT.

SALEM, OREGON

(1) OWNER: NORPAC FOODS, INC. Well Number: 930 W. Washington Stayton OR 97383

(2) TYPE OF WORK: Abandonment

(3) DRILL METHOD: Cable

(4) PROPOSED USE: Industrial

(5) BORE HOLE CONSTRUCTION: ABANDONMENT

HOLE SEAL: N/A

(6) CASING/LINER: N/A

(7) PERFORATIONS/SCREENS: N/A

(8) WELL TESTS: Minimum testing time is 1 hour

(9) LOCATION OF WELL by legal description: County MARION Township 6S N or S Range 2W E or W. WM. Section 8 SW 1/4 SE 1/4 Tax Lot 47463 Block 000 Subdivision Street Address of Well (or nearest address) 4755 Brooklake Rd. Salem, Ore. 97305

(10) STATIC WATER LEVEL: 58.5 ft. below land surface. Date 8-24-96

(11) WATER BEARING ZONES: Table with columns From, To, Estimated Flow Rate, SWL. Content: N/A

(12) WELL LOG: Abandonment of Well #2

WELL DATA: 12" casing from +1.5' to 99.5' 10" x 250' wall pipe from 96' - 100', 10" P.S. screen 100' - 130'; 10" pipe 130' - 185'; screen from 185' - 201'; 10" pipe from 201' - 205' ABANDONMENT PROCEDURE: Special standard was granted by Rob Carter on July 22, 1996 to abandon this well. The approved procedure approved & subsequently followed was to perforate the 12" casing from 95' to ground level. Then grout placed from bottom upward to near surface level. Perforations were cut totaling 564'; grout pipe placed to 202' + 150 sacks cement w/ 6 gallons water per sack pumped to within 60' of surface; an additional 24 sacks w/ 5% bentonite were mixed & pumped to within 33' of surface. 1 1/2 sacks holeplug (3/8") filled to +1.5'

Date started August 26, 1996 Completed August 27, 1996

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief. WWC Number: Signed: Date:

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief. WWC Number: 633/ Signed: Michael Waldrop Date: Sept 22, '96