Artesian pressure

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

6/3w-23P

| (4) OTYPYTO | | |
|---|-------------------------------------|---------------------|
| STATE ENGINEER, SALEM, OREGON 9731ALEM within 30 days from the date of well completion. | OREGONesse type or print) G 3 4 G ろ | State Permit No |
| STATE ENGINEER, SALEM, OREGON 97310 | NGINEATE OF OREGON | State Well No. |
| filed with the STATE | "NICHARD WELL IVELOUI | State Well No. 6/34 |

| (1) OWNER: | (11) WELL TESTS: Drawdown is amount wate lowered below static level | er level is |
|---|---|---|
| Name GLEN M. ROLOFSON | Was a pump test made? ☐ Yes 🕱 No If yes, by whom? | |
| Address 1273 BARNICK RD N.E | Yield: gal./min. with ft. drawdown a | fter hrs. |
| SALEM, OREGON | " " " | |
| (2) LOCATION OF WELL: | " " " " TO | <u>"</u> |
| County MARION Driller's well number III8 | Bailer test 45 gal./min. with IO ft. drawdown | after I hrs. |
| 14 14 Section 23 T. 6 S R. 3 W W.M. | Artesian flow g.p.m. Date | |
| Bearing and distance from section or subdivision corner | Temperature of water Was a chemical analysis mad | e? [Yes [No |
| | (12) WELL LOG: Diameter of well below casing | |
| | Depth drilled 105 ft. Depth of completed well | I05 ft. |
| | Formation: Describe by color, character, size of material an show thickness of aquifers and the kind and nature of the stratum penetrated, with at least one entry for each chang | d structure, and |
| | stratum penetrated, with at least one entry for each change | ge of formation. |
| (a) THIND OF THORY (I I I) | MATERIAL FI | ROM TO |
| (3) TYPE OF WORK (check): | TOP SOIL |) 3 |
| Yew Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐ | BROWN CLAY | 3 25 |
| pandonment, describe material and procedure in Item 12. | BROWN SANDY SILT | 25 40 |
| (4) PROPOSED USE (check): (5) TYPE OF WELL: | BROWN CLAY WITH SAND | 10 60 |
| Domestic 🛣 Industrial 🗌 Municipal 📋 Rotary 📋 Driven 🗍 | | 50 75 |
| rrigation Test Well Other Cable I Jetted | BROWN SAND & GRAVEL | 75 IO5 |
| Dug | | |
| (6) CASING INSTALLED: Threaded Welded X | | |
| 6 | | |
| " Diam. from ft. to ft. Gage | | |
| " Diam, from ft, to ft. Gage | | |
| 7) PERFORATIONS: Perforated? X Yes \(\square\) No | | |
| Type of perforator used MTLLS | SET PUMP AT 95 FR. | |
| size of perforations in. by I in. | | |
| 60 perforations from 93 ft. to 103 ft. | | |
| perforations from ft. to ft. | | |
| perforations from | | |
| perforations from ft. to ft. perforations from ft. to ft. | | |
| | 1 1 | |
| 8) SCREENS: Well screen installed? Yes Xno | | |
| Manufacturer's Name | | |
| Model No. | | |
| am Slot size Set from ft. to ft. | Work started JAN. 18 19 66 Completed JAN. | 26 I966 |
| Diam. Slot size Set from ft. to ft. | Date well drilling machine moved off of well JAN 26 | I966 19 |
| 9) CONSTRUCTION: | (13) PUMP: | |
| Vell seal—Material used in seal | Monute about 1 N | |
| Depth of seal 20 ft. Was a packer used? | Manufacturer's Name | |
| Diameter of well bore to bottom of seal | | *************************************** |
| Vere any loose strata cemented off? Yes No Depth | Water Well Contractor's Certification: | |
| Vas a drive shoe used? ▼Yes □ No | This well was drilled under my jurisdiction and | this report is |
| Vas well gravel packed? 🗌 Yes 🔼 No 💮 Size of gravel: | true to the best of my knowledge and belief. | - |
| ravel placed from ft. to ft. | NAME WILLAMETTE DRILLING CO | |
| Pid any strata contain unusable water? 🗌 Yes 📋 No | (Person, firm or corporation) (Type or | |
| ype of water? depth of strata | Address RT. 2 BOX 276 SALEM, OREGO |) IN |
| lethod of sealing strata off | Drilling Machine Operator's License No | |
| 10) WATER LEVELS: | E MAN O | •••••• |
| static level 54 ft. below land surface Date 1/26/66 | [Signed] 6 mel O. Beles | |
| | (Water Well Contractor) Contractor's License No. 2 Date JAN. 26 | 3 T966 |
| Artesian pressure lbs. per square inch Date | Contractor's License No. 2 Date JAN. 26 | ,49 |