

**WATER WELL REPORT**  
STATE OF OREGON

MARI 5107

**RECEIVED**

OCT 23 1981

State Well No.

65/3w-24aa

WATER RESOURCES DEPT.

State Permit No.

6-9427

SALEM, OREGON

**(1) OWNER:**

Name Gordon Zielinski  
Address 1301 Mandarin St. N.E.  
City Salem, Oregon 97303 State

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandonment   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

**(4) PROPOSED USE (check):**

Drilled  Air  Driven   
Rotary Mud  Dug  Domestic  Industrial  Municipal   
Cable  Bored  Irrigation  Test Well  Other   
Thermal: Withdrawal  ReInjection

**(5) CASING INSTALLED:**

Steel  Threaded  Plastic  Welded   
"Diam. from +1 ft. to 110 ft. Gauge .250

**LINER INSTALLED:**

"Diam. from ..... ft. to ..... ft. Gauge .....

**(6) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used Torch  
Size of perforations 1/4 in. by 6 in.  
30 perforations from 105 ft. to 110 ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name .....

Type ..... Model No. ....

Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.

Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.

**WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

test 150 gal./min. with drill stem at 105 ft. 1 hrs.

Artesian flow g.p.m.

**(9) CONSTRUCTION:**

Special standards: Yes  No

Well seal—Material used Portland Cement and 5% bentonite

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 7 1/2 sacks

How was cement grout placed? pumped in thru conductor pipe

Was pump installed? ..... Type ..... HP ..... Depth ..... ft.

Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.

Did any strata contain unusable water?  Yes  No

Type of Water? ..... depth of strata .....

Method of sealing strata off .....

Was well gravel packed?  Yes  No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County Marion Driller's well number 2392

NE 1/4 NE 1/4 Section 24 T. 6S R. 3W W.M.

Tax Lot # ..... Lot ..... Blk ..... Subdivision .....

Address at well location: 8298 River Rd. N.E. Salem

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 57 ft.

Static level 41 ft. below land surface. Date 9/12/81

Artesian pressure ..... lbs. per square inch. Date .....

**(12) WELL LOG:**

Diameter of well below casing .....

Depth drilled 110 ft. Depth of completed well 110 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	26	
Gray Clay	26	39	
Brown Clay	39	57	
Cemented Brown Sand and Gravel	57	99	
Loose Brown Sand and Gravel	99	110	

Work started 9/12/81 19 Completed 9/12/81 19

Date well drilling machine moved off of well 9/12/81 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas L Davis (Drilling Machine Operator) Date 9/12/81

Drilling Machine Operator's License No. XX-752

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name WILLAMETTE DRILLING CO. (Type or print)

Address 7365 O'Neil Rd. N.E. Salem, Oregon 97303

[Signed] Dallas L Davis (Water Well Contractor)

Contractor's License No. 561 Date 9/12/81, 19.....