

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

5
MAR 24

RECEIVED

STATE OF OREGON
(Please type or print)
(Do not write above this line)

OCT 23 1974
State Well No. 6S13W-24

STATE ENGINEER
SALEM, OREGON
State Permit No.

(1) OWNER:

Name Homer Zielinski
Address Route 1, Box 69
Gervais, Oregon 97026

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6." Diam. from 0 ft. to 78 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used torch
Size of perforations 1/8 in. by 3 in.
20 perforations from 78 ft. to 75 1/2 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level
Was a pump test made? Yes No If yes, by whom?
d: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 36 gal./min. with 1 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite Baroid
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No. Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 74-4
1/4 Section 24 T. 6 S. R.3 W. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft.
Static level 25 ft. below land surface. Date 10-16-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 inch
Depth drilled 78 ft. Depth of completed well 78 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|-------------------------|------|----|-----|
| Top soil | 0 | 10 | |
| Brown clay | 10 | 20 | |
| Clay and silt | 20 | 45 | |
| Sand and gravel (water) | 45 | 65 | 25 |
| Gravel med. | 65 | 78 | 25 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Work started 10-15 1974 Completed 10-21 1974
Date well drilling machine moved off of well 10-21 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Thomas D. Flores Date 10-22, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 978

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Flores Well Drilling Company
(Person, firm or corporation) (Type or print)

Address Rt. 1, Box 56, Gervais, Ore. 97026

[Signed] Thomas D. Flores
(Water Well Contractor)

Contractor's License No. 590 Date 10-22, 1974