

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 21 1966

MARI... 5/48

WATER WELL REPORT

State Well No. 6/3w-24  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name ROBERT ZIELINSKI  
Address RT. 1 BOX 276 59  
GERVAIS, OREGON.

(2) LOCATION OF WELL:

County MARION Driller's well number II46  
1/4 Section 24 T. 6 R. 5 S. 3 W. W.M.  
Bearing and distance from section or subdivision corner  
WELL DRILLED AT RT. 2 BOX 270  
SALEM, OREGON.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
" Diam. from 8 ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from TOP ft. to I34-I0" ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used MILLS  
Size of perforations 3/8 in. by 2 in.  
580 perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from 70 ft. to BOTTOM ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal PUTTLE CLAY &  
Depth of seal 20 ft. Was a packer used? \_\_\_\_\_  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 36 ft. below land surface Date 6/II/66  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? DRILLER  
Yield: 450 gal./min. with 83 ft. drawdown after 4 hrs.  
" 400 " " 74 " " 4 "  
" 370 " " 69 " " 4 "  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing \_\_\_\_\_  
Depth drilled I34 - I0" Depth of completed well I34 - I0"  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	20
SILTY YELLOW CLAY	20	45
BROWN FINE SAND	45	60
BROWN SAND SMALL PEA GRAVEL	60	65
A LITTLE LARGER GRAVEL & SAND	65	80
<del>BLACK WASHED GRAVEL &amp; SAND</del>	<del>80</del>	<del>95</del>
BLACK WASHED GRAVEL & SAND LOOSE	80	95
BROWN TIGHT SAND & GRAVEL	95	II5
BROWN SAND & GRAVEL LOOSE	II5	I34
BLACK SHALE	I34-I0"	

Work started MAY 17 1966 Completed JUNE II 1966  
Date well drilling machine moved off of well JUNE II 1966

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.  
(Person, firm or corporation) (Type or print)  
Address RT. 2 BOX 276 SALEM, OREGON.

Drilling Machine Operator's License No. 74

[Signed] Emil O. Beier  
(Water Well Contractor)

Contractor's License No. 2 Date JUNE II 1966