

5190
M 121...

WATER WELL REPORT
STATE OF OREGON

State Well No. 6/3W-24N (1)
State Permit No. G-543

(1) OWNER:

Name Allen Lee
Address 7708 O'Neil Road
Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
SW 1/4 SW 1/4 Section 24 T. 6S R. 3W W.M.
Bearing and distance from section or subdivision corner
666 ft. North and 80 ft East of the
S.W. corner of Sec. 24, Sp. 6 S. R. 3 W.
of Will. Mer. in Marion County, Oregon

TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from Top ft. to 112 ft. Gage #277
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
SIZE of perforations 3/8 in. by 1 1/2 in.
288 perforations from 80 ft. to 112 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

CONSTRUCTION:

Well gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 20 ft.
Material used in seal— Puddled Clay
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 36 ft. below land surface Date 6/8/57
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Allen Lee Date 6-9, 1957
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below state level E.O. Beier
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" Pump Test Below " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 112 ft. Depth of completed well 112 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	2
Yellow Clay	2	45
Blue Clay	45	58
Black Sand	58	63
Yellow sand & fine gravel	63	68
Yellow sand & Gravel (Water)	68	112
Pump Test		
500 G.P.M.	@	70 ft.
450 G.P.M.	@	67
400 G.P.M.	@	62
370 G.P.M.	@	62
300 G.P.M.	@	58
270 G.P.M.	@	53
200 G.P.M.	@	51
140 G.P.M.	@	44

Work started May 20-57 Completed 6/8/57 19

(13) PUMP:

Manufacturer's Name Johnson
Type: Turbine H.P. 7 1/2

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Emil O. Beier
(Person, firm, or corporation) (Type or print)

Address 7555 O'Neil Road, Salem, Oregon

Driller's well number 341

[Signed] Emil O. Beier
(Well Driller)

License No. 89 Date 6/8/57, 19