NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT CEIVED

STATE OF OREGON MAY 24 1977 State Well No. 65/11-W-25

are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Do	(Please type or print)	RESC	No.	

(1) OWNER:	(10) LOCATION OF WELL:			
Name Fred and Genevieve Hug	County Marion Driller's well number XX 2036			
AddressRt. 1 Box 108	14 14 Section 25 T. 6S R. 2W W.M.			
Mt. Angel, Oregon 97362	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):	and distance from section of subdivision control			
New Well 🗓 Deepening 🗌 Reconditioning 🔲 Abandon 🗀				
If abandonment, describe material and procedure in Item 12.	(11) THATEUR LENYING CO			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.			
Rotany & Drivon [7]	Depth at which water was first found 60 ft.			
Cable	Static level 43 ft. below land surface. Date 5/6/77			
Oug   Bored   Irrigation Test Well   Other	Artesian pressure lbs. per square inch. Date			
CASING INSTALLED: Threaded   Welded K				
	(12) WELL LOG: Diameter of well below casing			
8" Diam. fromtopft. to141ft. Gage250	Depth drilled 141 ft. Depth of completed well 141 ft.			
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials;			
Danie Holli	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in			
PERFORATIONS: Perforated? W Yes   No.	position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used Mills Knife	MATERIAL From To SWL			
Size of perforations 3/8 in. by $2 \times 2 3/4$ in.				
896 perforations from 90 ft. to 139 ft.				
perforations fromft. toft.	Brown Clay			
<u>-</u>	Brown Sandy Gravel 73 85			
perforations from ft. to ft.	Brown Sand add Gravel 85 141			
(7) SCREENS: Well screen installed? □ Yes \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	Blown Saild and Graver 05 141			
Manufacturer's Name				
Type Model No				
Diam Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
O THE T PROGRES Drowdown is smooth mater land in				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? 🛚 Yes 🗆 No If yes, by whom? driller				
yield: 500 gal./min. with 9 ft. drawdown after 2 hrs.				
" " "				
" " "				
Bailer test gal./min. with ft. drawdown after hrs.				
Artesian flow g.p.m.				
gerature of water 53 Depth artesian flow encountered ft.	Work started 5/3/77 19 Completed 5/6/77 19			
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5/6/77 19			
	D. W			
Well seal—Material usedPortland Cement	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.			
Well sealed from land surface toft_	Materials used and information reported above are true to my			
Diameter of well bore to bottom of seal12 in.	best knowledge and belief.			
Diameter of well bore below seal8 in.	[Signed] Allos J. Occus. Date 5/7/77, 19			
Number of sacks of cement used in well seal1sacks	Drilling Machine Operator's License No. 7.5.2			
How was cement grout placed? Poured in from the Top	Drining Machine Operator's Encense No. 2.22			
	Water Well Contractor's Certification:			
	This well was drilled under my jurisdiction and this report is			
Variable of the State of the St	true to the best of my knowledge and belief.			
Was a drive shoe used? X Yes   No Plugs Size: location ft.	Name Willamette Drilling Co. (Type or print)			
Did any strata contain unusable water? 🗌 Yes 🔏 No				
Type of water? depth of strata	Address 1450 Barnick Rd. NE Salem, Oregon 97303			
Method of sealing strata off	15: mas & Ollan & Daniel			
Was well gravel packed? [ Yes W No Size of gravel:	[Signed] Water Well Contractor)			
Gravel placed fromft. toft.	Contractor's License No. 56. Date 5/7/77 19			
It.	Contractor's License No. 9.16.4			