

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER WELL REPORT

MAR 5 1977
48/3W-25
State Well No. _____
State Permit No. _____

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON

(Please type or print)

(Do not write above this line)

NOV - 9 1977

(1) OWNER:

WATER RESOURCES DEPT.

Name Raymond D. Schreiner
Address 7641 35th Ave. NE Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Cable Dug Driven Jetted Bored Domestic Industrial Municipal Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

..... 6 " Diam. from top ft. to 99 ft. Gage 250
..... " Diam. from ft. to ft. Gage
..... " Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
.....
.....
.....
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....

(9) CONSTRUCTION:

Well seal—Material used Portland Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
How was cement grout placed? poured in from the top

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2090
..... 1/4 1/4 Section 25 T. 6S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 54 ft.
Static level 45 ft. below land surface. Date 9/10/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing

Depth drilled 99 ft. Depth of completed well 99 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	49	
Brown Clay and Sand	49	54	
Brown Sand and Gravel Some Gravel	54	68	
Brown Sand & Gravel, cemented	68	89	
Brown Sand and Gravel	89	99	
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			
.....			

Work started 9/10/77 19 Completed 9/10/77 19
Date well drilling machine moved off of well 9/10/77 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dallas L. Davis Date 9/10/77, 19.....
(Drilling Machine Operator)
Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Willamette Drilling Co.
(Person, firm or corporation) (Type or print)
Address 1450 Barnick Rd. NE Salem, Oregon 97303
[Signed] Dallas L. Davis
(Water Well Contractor)
Contractor's License No. 561 Date 9/10/77, 19.....