

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print) STATE ENGINEER
SALEM, OREGON
(Do not write above this line)

MAY 13 1974
State Well No. 65/3W-25
State Permit No. 6-6202

5197
MAY 1974

(1) OWNER:

Name Jess Tryan % Willamette Lutheran Home
Address 7693 Wheatland Road
Salem, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from top ft. to 84 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills
Size of perforations 7/16 in. by 2 3/4 in.
620 perforations from 39 ft. to 82 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 350 gal./min. with 7 ft. drawdown after 4 hrs.
400 " " 9 " " same "
500 " " 11 " " same "
Bailer test 600 gal./min. with 12 ft. drawdown after same hrs.
700 " " 14 " " same
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 1828
1/4 1/4 Section 25 T. 6 R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 20 ft.
Static level 3 ft. below land surface. Date 5-9-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 84 ft. Depth of completed well 84 ft.
Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Brown Soil	0	2	
Brown silty Clay	2	20	
Brown gravelly Sand	20	35	
Brown Gravel	35	48	
Brown Cemented Sand & gravel	48	52	
Brown gravel	52	74	
Brown sand and gravel	74	79	
Brown gravel	79	84	

Work started May 3, 1974 Completed May 9, 1974
Date well drilling machine moved off of well May 9, 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.
[Signed] Emil O. Beer Date May 10, 1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.
Name WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)
Address 7641 35th Ave. NE Salem, Oregon
[Signed] Emil O. Beer
(Water Well Contractor)
Contractor's License No. 2 Date May 10, 1974